

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: Gary Robinson Homes LLC

Building: 12-50028955

Electrical: 12-50028955

Address: 265 Tactical Drive

Insulation: 12-50028955

Bunnlevel NC 28323

Plumbing: 12-50028955

Mechanical: 12-50028955

MFG Home: NANANANANANA

Date: 11-26-2012

Building Official: BSutton

PREPARED 11/21/12, 14:04:43
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 7
DATE 11/26/12

ADDRESS : 265 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : 210 HWY DEV #16 PHONE : (910) 977-2562
PARCEL : 01-0547- - -0024- -18-
APPL NUMBER: 12-50028955 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/17/2012 08:44 AM DJOHNSON --
GWEN OAKS SUBD LOT 16
210 SOUTH ABOUT 14 MILES PAST SOUTH
HARNETT ELEM SCHOOL ON LEFT

STRUCTURE: 000 000 29X45 4 BR ATT GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : CTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 02	8/01/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002259349
	8/01/12	AP	T/S: 07/31/2012 11:48 AM DJOHNSON ----- T-POLE PASSED NEED PREMISE # -----
B103 01	8/03/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002260784
	8/03/12	AP	Premise number is 586 06 206. T/S: 08/03/2012 01:01 PM MREARIC -----
A814 01	8/03/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002260792
	8/03/12	AP	265 tactical dr lot 16 bunnlevel 28323 T/S: 08/03/2012 03:28 PM TWARD -----
B105 01	8/09/12	JH	R*OPEN FLOOR VRU #: 002262921
	8/09/12	AP	-----
R425 01	8/29/12	JH	FOUR TRADE ROUGH IN VRU #: 002272029
	8/29/12	DA	Missing roof boots OK TO SIDE & INSULATE -----
I129 01	8/31/12	FS	R*INSULATION INSPECTION VRU #: 002273290
	8/31/12	AP	T/S: 08/31/2012 03:02 PM FSPIVEY -----
R425 02	8/31/12	FS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002273456
	8/31/12	AP	T/S: 08/30/2012 02:55 PM DJOHNSON ----- T/S: 08/31/2012 03:05 PM FSPIVEY -----
H824 01	10/16/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002291706
	10/16/12	AP	T/S: 10/16/2012 08:55 AM SSTEWARD ----- T/S: 10/16/2012 08:55 AM SSTEWARD -----
R429 01	10/30/12	DT	FOUR TRADE FINAL VRU #: 002297281
	10/30/12	DA	T/S: 10/30/2012 10:58 AM DETAYLOR ----- Power issued
R429 02	11/20/12	MR	FOUR TRADE FINAL VRU #: 002305563
	11/20/12	DP	T/S: 11/20/2012 01:15 PM MREARIC ----- the crawlspace AHU must be on a 30 amp breaker max. / the wood at the crawlspace door must be treated or painted / the water heater must discharge per code to an area where no personel or structural damage will result / rodent proof the found. drain 1:18 PM MREARIC -----
R429 03	11/26/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002307270
	11.26.12	APBS	T/S: 11/21/2012 10:34 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 265 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER : 210 HWY DEV #16
PARCEL : 01-0547- - -0024- -18-
APPL NUMBER: 12-50028955 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/17/2012 08:44 AM DJOHNSON --
GWEN OAKS SUBD LOT 16 **58606206**
210 SOUTH ABOUT 14 MILES PAST SOUTH
HARNETT ELEM SCHOOL ON LEFT

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE : (910) 977-2562

STRUCTURE: 000 000 29X45 4 BR ATT GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : CTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 02	8/01/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002259349
	8/01/12	AP	T/S: 07/31/2012 11:48 AM DJOHNSON ----- T-POLE PASSED NEED PREMISE # -----
B103 01	8/03/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002260784
	8/03/12	AP	Premise number is 586 06 206. T/S: 08/03/2012 01:01 PM MREARIC -----
A814 01	8/03/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002260792
	8/03/12	AP	265 tactical dr lot 16 bunnlevel 28323 T/S: 08/03/2012 03:28 PM TWARD -----
B105 01	8/09/12	JH	R*OPEN FLOOR VRU #: 002262921
	8/09/12	AP	-----
R425 01	8/29/12	JH	FOUR TRADE ROUGH IN VRU #: 002272029
	8/29/12	DA	Missing roof boots OK TO SIDE & INSULATE -----
I129 01	8/31/12	FS	R*INSULATION INSPECTION VRU #: 002273290
	8/31/12	AP	T/S: 08/31/2012 03:02 PM FSPIVEY -----
R425 02	8/31/12	FS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002273456
	8/31/12	AP	T/S: 08/30/2012 02:55 PM DJOHNSON ----- T/S: 08/31/2012 03:05 PM FSPIVEY -----
H824 01	10/16/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002291706
	10/16/12	AP	T/S: 10/16/2012 08:55 AM SSTEWARD ----- T/S: 10/16/2012 08:55 AM SSTEWARD -----
R429 01	10/30/12	TI	FOUR TRADE FINAL VRU #: 002297281

10/30/12 DADR

COMMENTS AND NOTES

ADDRESS . : 265 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . : 210 HWY DEV #16 PHONE : (910) 977-2562
PARCEL . . : 01-0547- - -0024- -18-
APPL NUMBER: 12-50028955 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 05/17/2012 08:44 AM DJOHNSON --
GWEN OAKS SUBD LOT 16
210 SOUTH ABOUT 14 MILES PAST SOUTH
HARNETT ELEM SCHOOL ON LEFT

STRUCTURE: 000 000 29X45 4 BR ATT GARAGE CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : CTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 02	8/01/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002259349
	8/01/12	AP	T/S: 07/31/2012 11:48 AM DJOHNSON ----- T-POLE PASSED NEED PREMISE # -----
B103 01	8/03/12	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002260784
	8/03/12	AP	Premise number is 586 06 206. T/S: 08/03/2012 01:01 PM MREARIC -----
A814 01	8/03/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002260792
	8/03/12	AP	265 tactical dr lot 16 bunnlevel 28323 T/S: 08/03/2012 03:28 PM TWARD -----
B105 01	8/09/12	JH	R*OPEN FLOOR VRU #: 002262921
	8/09/12	AP	-----
R425 01	8/29/12	JH	FOUR TRADE ROUGH IN VRU #: 002272029
	8/29/12	DA	Missing roof boots OK TO SIDE & INSULATE -----
I129 01	8/31/12	FS	R*INSULATION INSPECTION VRU #: 002273290
	8/31/12	AP	T/S: 08/31/2012 03:02 PM FSPIVEY -----
R425 02	8/31/12	FS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002273456
	8/31/12	AP	T/S: 08/30/2012 02:55 PM DJOHNSON ----- T/S: 08/31/2012 03:05 PM FSPIVEY -----
H824 01	10/16/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002291706
	10/16/12	AP	T/S: 10/16/2012 08:55 AM SSTEWARD ----- T/S: 10/16/2012 08:55 AM SSTEWARD -----
R429 01	10/30/12	DT	FOUR TRADE FINAL VRU #: 002297281
	10/30/12	DA	T/S: 10/30/2012 10:58 AM DETAYLOR ----- Power issued
R429 02	11/20/12	TI	FOUR TRADE FINAL VRU #: 002305563

11-20-12 DP-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 11/20/2012

PERMIT # 12-50028955

ADDRESS: 265 tactical dr.

1. install fall prevention devices on all windows more than 6' above grade
2. The ahu under the house is on a 40amp breaker ..30 is the max. for the unit
3. The 1x2 wood at the crawlspace access door must be treated or painted
4. The water heater discharge (per code) must lead to a place where it will not injure people or structure... not onto the wooden floor

Mike Rearic cell# (910) 984- 4772