

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 bedrooms      Design Flow (.1949): 360 gpd  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual       Well       Spring       Other  
 Evaluation Method:  Auger Boring       Pit       Cut  
 Type of Wastewater:                       Sewage       Industrial Process       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-14	G LS	VFR NS/HP					
		14-32"	SBK SCL	FR SS/SP					
		32"	SBK SL	FR SS/SP					PS .4
2		0-6	G LS	VFR NS/HP					
		6-34"	SBK SCL	FR SS/SP	10YR 7/2 R 30"				PS .4
3		0-6	G LS	VFR NS/HP					
		6-30"	SBK SCL	FR SS/SP	10YR 7/2 R 25"				PS .4
4		0-8	G LS	VFR NS/HP					
		8-32"	SBK SCL	FR SS/SP	10YR 7/2 R 24"				PS .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1945)			
System Type(s)	(1) P (1) A (1) S (1) C (1) R (1) D		
Site LTAR	.4	.4	