HTE# 12-5-28956

Harnett County Department of Public Health

Improvement Permit

27053

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: WIDE RO SANN HOMES LLC SUBDIVISION KENLAN FARMS NEW 🔀 Site Improvements required prior to Construction Authorization Issuance: Type of Structure: 5FD(51'×43 Proposed Wastewater System Type: 25% REDUCTION STEEM Projected Daily Flow: _ **GPD** Number of Occupants: 8 Number of bedrooms: Basement □Yes Pump Required: □Yes **257**0 ☐ May be required based on final location and elevations of facilities Type of Water Supply:

Community

Public

Well Distance from well 100 feet Five years Permit valid for: Permit conditions: ■ No expiration Authorized State Agent::

Date: 5 224 72 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1951, .1954, .1955, .1956, .1957, .1958. and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. PROPERTY LOCATION: Wine Ro ISSUED TO: SAVY HOMES LLC SUBDIVISION KENLAN FARMS LOT # 18 Facility Type: SEO (5) AH3) New ☐ Expansion ☐ Repair (See note below, if applicable) Brock Installation Requirements/Conditions Number of trenches Trench Spacing: _____ Feet on Center Septic Tank Size 1000 Exact length of each trench 75 gallons Soil Cover: 28-36 inches Pump Tank Size _____ gallons Trenches shall be installed on contour at a Trench Depth of: 40-478 (Maximum soil cover shall not exceed (Trench bottoms shall be level-to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. inches below pipe Aggregate Depth: _____ inches above pipe ____ inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: ____ This Construction Authorization is subject to revocation if the site plans plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. Authorized State Agent: Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch

