

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 2602005 Design Flow (.1949): 360 gpd
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 2-5	0-13"	G S	VFR NS/NP					
		13-48"	SBK SCL	F2 SS/NP					P5 .5
2		0-16"	G S	VFR NS/NP					
		16-32"	SBK SCL	F2 SS/NP					P5 .5
		32"	G S	VFR NS/NP					
3		0-26"	G S	VFR NS/NP	10727) 20"				VS
4		0-16"	G S	VFR NS/NP					
		16"	SBK SCL	F2 SS/NP	10727) 20 16"				VS
5		0-16"	G S	VFR NS/NP					
		16-42"	SBK SCL	F2 SS/NP					P5 .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	2570	BANK BLOC S	
Site LTAR	.5	.5	