

County of Harnett  
Building Inspections Department  
Planning Services

**Certificate of Compliance: \_\_\_ Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

**Permit Numbers**

Name: Gary Robinson Homes LLC

Building: 12-50029033

Electrical: 12-50029033

Address: 285 Tactical Drive

Insulation: 12-50029033

Bunnlevel NC 28323

Plumbing: 12-50029033

Mechanical: 12-50029033

MFG Home: NANANANANANA

Date: 11-26-2012

Building Official: BSutton

Harnett County

INSPECTOR: IVR

DATE 11/26/12

ADDRESS : 285 TACTICAL DR  
 CONTRACTOR : GARY ROBINSON HOMES LLC  
 OWNER : 210 HIGHWAY DEVELOPMENT LLC  
 PARCEL : 01-0547- - -0024- -19-  
 APPL NUMBER: 12-50029033 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 05/30/2012 09:15 AM VBROWN ----  
 285 TACTICAL DRIVE LILLINGTON 27546,  
 GWEN OAKS #17. 210S APPROX 14MI ON  
 LEFT.

SUBDIV: GWEN OAKS 63 LOTS  
 PHONE : (910) 977-2562  
 PHONE :

STRUCTURE: 000 000 40X38 3BDR 2.5BATH SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/10/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002263623
	8/10/12	AP	
A814 01	8/15/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002265882
	8/21/12	AP	285 TACTICAL DR LOT 17 BUNNLEVEL 28323----- T/S: 08/21/2012 01:04 PM TWARD -----
B103 01	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265874
	8/15/12	AP	T/S: 08/15/2012 02:24 PM DJOHNSON -----
B105 01	8/16/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002266765
	8/16/12	CA	T/S: 08/15/2012 02:24 PM DJOHNSON ----- PER BILLY -----
B105 02	8/17/12	DT	R*OPEN FLOOR VRU #: 002267151
	8/17/12	AP	
R425 01	9/06/12	JH	FOUR TRADE ROUGH IN VRU #: 002274983
	9/06/12	DA	1)Ground metal boxes on front of house.2)Fire chasto right of refriderator.3)Missing air barrier in chase to right of refrig.4)Missing receptacle in kitchen to left of pantry door.5)Add 2x4 blocks in top plate above fire place & strap with 24" straps.6)Fire caulk top of chase in bed2 @ closet & laundry room chase.7)Missing header over master bed door.8)Missing hurricaine straps in master bed room on C3 truss.9)Missing receptacle on back of house accessible from grade.
I129 01	9/11/12	JH	R*INSULATION INSPECTION VRU #: 002276624
	9/11/12	AP	
R425 02	9/11/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002277085
	9/11/12	AP	T/S: 09/10/2012 02:51 PM DJOHNSON ----- PLEASE SCHEDULE DISAPPROVED ROUGH INS WITH INSULATION. IF THESE ARE NOT SCHEDULED AT THE SAME TIME THE INSPECTION WILL BE CANCELLED.
H824 01	10/16/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002291714
	10/16/12	AP	T/S: 10/16/2012 08:56 AM SSTEWARD ----- T/S: 10/16/2012 08:56 AM SSTEWARD -----
R429 01	10/30/12	DT	FOUR TRADE FINAL VRU #: 002297299
	10/30/12	DA	T/S: 10/30/2012 10:58 AM DETAYLOR ----- Power issued
R429 02	11/20/12	MR	FOUR TRADE FINAL VRU #: 002305589

ADDRESS : 285 TACTICAL DR  
CONTRACTOR : GARY ROBINSON HOMES LLC  
OWNER : 210 HIGHWAY DEVELOPMENT LLC  
PARCEL : 01-0547- - -0024- -19-  
APPL NUMBER: 12-50029033 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS  
PHONE : (910) 977-2562  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
	11/20/12	DP	T/S: 11/20/2012 01:20 PM MREARIC the wood at the crawlspace door must bew paintedred or treated / deck must have lateral bracing per code appendix M / provide a rodent-proofed found. drain
R429 03	11/26/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002307262 T/S: 11/21/2012 10:33 AM VBROWN

----- COMMENTS AND NOTES -----

ADDRESS : 285 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS  
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562  
 OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :  
 PARCEL : 01-0547- - -0024- -19-  
 APPL NUMBER: 12-50029033 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 05/30/2012 09:15 AM VBROWN ----  
 285 TACTICAL DRIVE LILLINGTON 27546,  
 GWEN OAKS #17. 210S APPROX 14MI ON  
 LEFT. **17100690**

STRUCTURE: 000 000 40X38 3BDR 2.5BATH SFD W GAR CRAWL  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/10/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002263623
	8/10/12	AP	
A814 01	8/15/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002265882
	8/21/12	AP	285 TACTICAL DR LOT 17 BUNNLEVEL 28323----- T/S: 08/21/2012 01:04 PM TWARD -----
B103 01	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265874
	8/15/12	AP	T/S: 08/15/2012 02:24 PM DJOHNSON -----
B105 01	8/16/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002266765
	8/16/12	CA	T/S: 08/15/2012 02:24 PM DJOHNSON ----- PER BILLY -----
B105 02	8/17/12	DT	R*OPEN FLOOR VRU #: 002267151
	8/17/12	AP	
R425 01	9/06/12	JH	FOUR TRADE ROUGH IN VRU #: 002274983
	9/06/12	DA	1)Ground metal boxes on front of house.20Fire chasto right of refriderator.3)Missing air barrier in chase to right of refrig.4)Missing receptacle in kitchen to left of pantry door.5)Add 2x4 blocks in top plate above fire place & strap with 24" straps.6)Fire caulk top of chase in bed2 @ closet & laundry room chase.7)Missing header over master bed door.8)Missing hurricaine straps in master bed room on C3 truss.9)Missing receptacle on back of house accessible from grade.
I129 01	9/11/12	JH	R*INSULATION INSPECTION VRU #: 002276624
	9/11/12	AP	
R425 02	9/11/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002277085
	9/11/12	AP	T/S: 09/10/2012 02:51 PM DJOHNSON ----- PLEASE SCHEDULE DISAPPROVED ROUGH INS WITH INSULATION. IF THESE ARE NOT SCHEDULED AT THE SAME TIME THE INSPECTION WILL BE CANCELLED.
H824 01	10/16/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002291714
	10/16/12	AP	T/S: 10/16/2012 08:56 AM SSTEWARD ----- T/S: 10/16/2012 08:56 AM SSTEWARD -----
R429 01	10/30/12	TI	FOUR TRADE FINAL VRU #: 002297299
	<u>10/30/12</u>	<u>DA DA</u>	

ADDRESS : 285 TACTICAL DR  
 CONTRACTOR : GARY ROBINSON HOMES LLC  
 OWNER : 210 HIGHWAY DEVELOPMENT LLC  
 PARCEL : 01-0547- - -0024- -19-  
 APPL NUMBER: 12-50029033 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 05/30/2012 09:15 AM VBROWN ----  
 285 TACTICAL DRIVE LILLINGTON 27546,  
 GWEN OAKS #17. 210S APPROX 14MI ON  
 LEFT.

SUBDIV: GWEN OAKS 63 LOTS  
 PHONE : (910) 977-2562  
 PHONE :

STRUCTURE: 000 000 40X38 3BDR 2.5BATH SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 3.00

PROPOSED USE : SFD

SEPTIC - EXISTING? : NEW TANK

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/10/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002263623
	8/10/12	AP	
A814 01	8/15/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002265882
	8/21/12	AP	285 TACTICAL DR LOT 17 BUNNLEVEL 28323----- T/S: 08/21/2012 01:04 PM TWARD -----
B103 01	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265874
	8/15/12	AP	T/S: 08/15/2012 02:24 PM DJOHNSON -----
B105 01	8/16/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002266765
	8/16/12	CA	T/S: 08/15/2012 02:24 PM DJOHNSON ----- PER BILLY -----
B105 02	8/17/12	DT	R*OPEN FLOOR VRU #: 002267151
	8/17/12	AP	
R425 01	9/06/12	JH	FOUR TRADE ROUGH IN VRU #: 002274983
	9/06/12	DA	1)Ground metal boxes on front of house.20Fire chasto right of refriderator.3)Missing air barrier in chase to right of refrig.4)Missing receptacle in kitchen to left of pantry door.5)Add 2x4 blocks in top plate above fire place & strap with 24" straps.6)Fire caulk top of chase in bed2 @ closet & laundry room chase.7)Missing header over master bed door.8)Missing hurricaine straps in master bed room on C3 truss.9)Missing receptacle on back of house accessible from grade.
I129 01	9/11/12	JH	R*INSULATION INSPECTION VRU #: 002276624
	9/11/12	AP	
R425 02	9/11/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002277085
	9/11/12	AP	T/S: 09/10/2012 02:51 PM DJOHNSON ----- PLEASE SCHEDULE DISAPPROVED ROUGH INS WITH INSULATION. IF THESE ARE NOT SCHEDULED AT THE SAME TIME THE INSPECTION WILL BE CANCELLED.
H824 01	10/16/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002291714
	10/16/12	AP	T/S: 10/16/2012 08:56 AM SSTEWARD ----- T/S: 10/16/2012 08:56 AM SSTEWARD -----
R429 01	10/30/12	DT	FOUR TRADE FINAL VRU #: 002297299
	10/30/12	DA	T/S: 10/30/2012 10:58 AM DETAYLOR ----- Power issued
R429 02	11/20/12	TI	FOUR TRADE FINAL VRU #: 002305589

Harvett County

INSPECTOR: IVR

DATE 11/20/12

ADDRESS . . : 285 TACTICAL DR  
 CONTRACTOR : GARY ROBINSON HOMES LLC  
 OWNER . . . : 210 HIGHWAY DEVELOPMENT LLC  
 PARCEL . . . : 01-0547- - -0024- -19-  
 APPL NUMBER: 12-50029033 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS  
 PHONE : (910) 977-2562  
 PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
--------	------------------------	----------------	---------------------------------

11-20-12 DP-MR

COMMENTS AND NOTES

## **HARNETT COUNTY**

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

**DATE:** 11/20/2012

**PERMIT #** 12-50028955

**ADDRESS:** 265 tactical dr.

1. The 1x2 wood at the crawlspace access door must be treated or painted
2. Deck must have lateral bracing per appendix M
3. Provide a rodent proofed drain on foundation

**Mike Rearic      cell# (910) 984- 4772**