

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____ Date Evaluated: 6/11/2012
 Address: _____ Design Flow (.1949): _____ Property Size: _____
 Proposed Facility: _____ Property Recorded: _____
 Location of Site: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

| P R O F I L E # | .1940 Landscape Position/ Slope % | Horizon Depth (In.) | SOIL MORPHOLOGY .1941 | | OTHER PROFILE FACTORS | | | | Profile Class & LTAR |
|--------------------------------------|--|---------------------------|--------------------------------|------------------------------------|------------------------------------|------------------------------|-------------------------|-------------------------|----------------------------|
| | | | .1941 Structure/ Texture | .1941 Consistence Mineralogy | .1942 Soil Wetness/ Color | .1943 Soil Depth (IN.) | .1956 Sapro Class | .1944 Restr Horiz | |
| | 45-78 | 0-32 | G/LS | VFrNSNP | | | | | |
| | | 22-48 | G/SL | VFrNSNP | | | | | 5.8 |
| | | 0-33 | G/LS | VFrNSNP | | | | | |
| | | 33-40 | G/SL | VFrNSNP | | | | | |
| | | 0-18 | G/LS | VFrNSNP | | | | | |
| | | 18-34 | SbK/SL | FrNSNP | 10YR 7/1 32 | | | | PS.5 |
| | | 0-48 | G/LS | VFrNSNP | | | | | 5.8 |
| | | 0-39 | G/LS | VFrNSNP | 10YR 5/2 35 ¹¹ | | | | PS.8 |


| | | | |
|-------------------------|----------------|---------------|---------------------------------|
| Description | Initial System | Repair System | Other Factors (.1946): |
| Available Space (.1945) | | | Site Classification (.1948): PS |
| System Type(s) | Pump 25% | Pump 25% | Evaluated By: Bm |
| Site LTAR | .8 | .8 | Others Present: OT |



MAP NO. 2012-86

MAP REFERENCE: MAP NO. 2012-86

SITE PLAN APPROVAL
 DISTRICT BARBECUE USE SFD
 3 BEDROOMS
 5-31-12
 [Signature]



Move house 65' from
 10 ft R/LP

65'

"JUNO DRIVE" 50' RW

- MINIMUM BUILDING SET BACKS
- FRONT YARD — 30'
 - REAR YARD — 25'
 - SIDE YARD — 10'
 - CORNER LOT SIDE YARD — 20'
 - MAXIMUM HEIGHT — 35'



| | | | | | | | |
|---|--------------------|--------------------|---------|---|--|-------------------------|--|
| SURVEY FOR: PROPOSED PLOT PLAN - LOT - 140 TINGEN POINTE S/D, PHASE - 5 | | | | BENNETT SURVEYS, INC. 1662 CLARK RD., LILLINGTON, N.C. 27546 (910) 893-5252 | | JOB NO. 12232 C-1080 | |
| TOWNSHIP | BARBECUE | COUNTY | HARNETT | | | SURVEYED BY: | |
| STATE: NORTH CAROLINA | | DATE: MAY 24, 2012 | | SCALE: 1" = 40' | | DRAWN BY: RVB | |
| ZONE | WATERSHED DISTRICT | TAX PARCEL ID# | | CHECKED & CLOSURE BY: | | FIELD BOOK | |
| RA-20R | | | | | | DRAWING NO. 12232 | |