

-----  
 ADDRESS : 520 JUNO DR  
 CONTRACTOR : WYNN CONSTRUCTION, INC.  
 OWNER : THE HARNETT LAND GROUP II LLC  
 PARCEL : 03-9576-01- -0088- -27-  
 APPL NUMBER: 12-50029197 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 06/19/2012 01:12 PM JBROCK ----  
 HWY 27 W LEFT OMAHA DR LEFT ON JUNO LOT  
 123

SUBDIV: TINGEN POINTE PH 5 33LOTS  
 PHONE : (919) 528-1347  
 PHONE :

-----  
**STRUCTURE: 000 000 50X55 3BDR MONO W/ GARAGE**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3000000.00  
 SEPTIC - EXISTING? . . . . : NEW TANK  
 PROPOSED USE . . . . . : SFD  
 WATER SUPPLY . . . . . : COUNTY

-----  
**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	8/31/12	MR	R*PLUMB UNDER SLAB VRU #: 002272367 T/S: 08/31/2012 02:18 PM MREARIC -----
B114 01	9/04/12	MR	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002273696 9/04/12 AP T/S: 09/04/2012 10:27 AM MREARIC -----
A814 01	9/04/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002273845 8/31/12 AP T/S: 08/31/2012 02:25 PM DJOHNSON ----- 520 JUNO DR LOT 123 BROADWAY 27505-----
R425 01	9/24/12	TI	T/S: 08/31/2012 03:48 PM TWARD ----- FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002280436 9-24-12 DA-MR T/S: 09/20/2012 02:44 PM VBROWN -----

-----  
COMMENTS AND NOTES

Roof not Finished  
 OK To side + ins.

**DAVID MILLER, PE**  
6300 Creedmoor Rd, STE 170#363  
Raleigh, NC 27612  
(919) 422-8932 (Office) ; DAVE@DMA-PA.COM

August 29, 2012

WYNN CONSTRUCTION  
2550 CAPITAL DRIVE  
SUITE 105  
CREEDMOOR, NC 27522

E mailed to: [jason@wynnconstruct.com](mailto:jason@wynnconstruct.com) ; [keiths@davidsonandjones.com](mailto:keiths@davidsonandjones.com)

RE: Engineering – Field Observation  
Lot 123 Tingen Pointe Subdivision  
Lillington, Harnett County, NC  
Job No.: 12DDM-0829B

To whom it may concern/ Inspections Dept.:

The undersigned arrived on-site to observe and test the in-place fill conditions for the above referenced site. Based on the testing (Per ASTM Special publication 399) the fill materials (Tan silty sands (Unified Soil Classification System – SM)) were adequately compacted (95% Standard Proctor) and adequate to support the planned structure. Based on the observations and testing the bearing soils for the footings will provide adequate support.

Sincerely,

David Miller, PE

DEM/12DDM-0829B



ADDRESS : 520 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS  
 CONTRACTOR : WYNN CONSTRUCTION, INC. PHONE : (919) 528-1347  
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :  
 PARCEL : 03-9576-01- -0088- -27-  
 APPL NUMBER: 12-50029197 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 06/19/2012 01:12 PM JBROCK ----  
 HWY 27 W LEFT OMAHA DR LEFT ON JUNO LOT  
 123

**STRUCTURE: 000 000 50X55 3BDR MONO W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
P309 01	8/31/12	MR	R*PLUMB UNDER SLAB VRU #: 002272367
	8/31/12	AP	T/S: 08/31/2012 02:18 PM MREARIC -----
B114 01	9/04/12	MR	R*BLDG MONO SLAB/TEMP SVC POLE VRU #: 002273696
	9/04/12	AP	T/S: 09/04/2012 10:27 AM MREARIC -----
A814 01	9/04/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002273845
	8/31/12	AP	T/S: 08/31/2012 02:25 PM DJOHNSON ----- 520 JUNO DR LOT 123 BROADWAY 27505----- T/S: 08/31/2012 03:48 PM TWARD -----
R425 01	9/24/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002280436
	9/24/12	DA	T/S: 09/20/2012 02:44 PM VBROWN ----- T/S: 09/24/2012 01:42 PM MREARIC ----- roof not finished, but ok to side and ins.
I129 01	9/26/12	TI	R*INSULATION INSPECTION VRU #: 002282788
	<u>9-26-12</u>	<u>AP-MR</u>	
R425 02	9/26/12	TI	FOUR TRADE ROUGH IN VRU #: 002282770
	<u>9-26-12</u>	<u>AP-MR</u>	

COMMENTS AND NOTES