

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 7/10/2002
 Proposed Facility: Design Flow (.1949): Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	L549	C-40	G/L5	VF-NSNP					5.8
		C-40	G/L5	VF-NSNP					5.8
		C-40	G/L5	VF-NSNP					5.8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): 5 Evaluated By: [Signature] Others Present:
Available Space (.1945)			
System Type(s)	256	256	
Site LTAR	.8	.8	

