
ADDRESS : 436 STONE CROSS DR SUBDIV: STONE CROSS
CONTRACTOR : AMERICAN HOMESMITH LLC PHONE : (919) 422-4128
OWNER : ODOM STEVEN C PHONE : (910) 257-3498
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/20/2012 10:00 AM JBROCK ----
HWY 210 FROM LILLINGTON TURN RIGTH ON
OVERHILLS RD RIGHT INTO STONECROSS LOT
70

STRUCTURE: 000 000 51X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/12	VC	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002257587
	7/27/12	CA	VOICE MESSAGE LEFT T/S: 07/27/2012 10:13 AM VBROWN ----- TRAVIS SENT EMAIL AT 9:26 CA INSP.
B101 02	7/31/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002258443
	7/31/12	AP	T/S: 07/30/2012 10:06 AM DJOHNSON -----
A814 01	8/10/12	TW	✓ ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002263499
	8/10/12	AP	436 STONE CROSS DR LOT 70 SPRING LAKE 28390----- T/S: 08/10/2012 03:02 PM TWARD -----
B103 01	8/10/12	FS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002263481
	8/10/12	CA	T/S: 08/10/2012 02:41 PM FSPIVEY -----
B103 02	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265825
	8/15/12	AP	-----
B105 01	8/27/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002271062
	8/27/12	AP	-----
E207 01	8/27/12	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002271054
	8/27/12	AP	-----
R427 01	9/17/12	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002279297

9-17-12 op TJ

----- COMMENTS AND NOTES -----

ADDRESS : 436 STONE CROSS DR SUBDIV: STONE CROSS
CONTRACTOR : AMERICAN HOMESMITH LLC PHONE : (919) 422-4128
OWNER : ODOM STEVEN C PHONE : (910) 257-3498
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/20/2012 10:00 AM JBROCK ----
HWY 210 FROM LILLINGTON TURN RIGH ON
OVERHILLS RD RIGHT INTO STONECROSS LOT
70

STRUCTURE: 000 000 51X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/12	VC	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002257587
	7/27/12	CA	VOICE MESSAGE LEFT T/S: 07/27/2012 10:13 AM VBROWN ----- TRAVIS SENT EMAIL AT 9:26 CA INSP.
B101 02	7/31/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002258443
	7/31/12	AP	T/S: 07/30/2012 10:06 AM DJOHNSON -----
A814 01	8/10/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002263499
	8/10/12	AP	436 STONE CROSS DR LOT 70 SPRING LAKE 28390----- T/S: 08/10/2012 03:02 PM TWARD -----
B103 01	8/10/12	FS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002263481
	8/10/12	CA	T/S: 08/10/2012 02:41 PM FSPIVEY -----
B103 02	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265825
	8/15/12	AP	-----
B105 01	8/27/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002271062
	8/27/12	AP	-----
E207 01	8/27/12	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002271054
	8/27/12	AP	-----
R427 01	9/17/12	JH	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002279297
	9/17/12	DP	1) Fire caulk drain & water lines in garage on house wall @ top & bottom plate. 2) Nail all holes in structural nail plates @ top plate on drain lines in garage. 3) Missing lvl header over kitchen window per plans. 4) Seal all cracks in air barriers @ canilevers in kitchen, dining room & living room. 5) Nail osb on studs to right of kitchen window. 6) Fire caulk drain & water lines @ top & bottom plates in half bath. 7) Label dryer duct length per code. 8) Seal cracks in air barriers under stairs on garage wall. 9) Missing air barriers & insulation under landing @ bottom of stairs. 10) Missing stud in hall @ top of stairs @ spare bath tub. 11) Missing fire caulk on all plumbing @ top & bottom plate throughout house. 12) Fire caulk hole @ pipe for tub drain for spare bath. 13) Missing baffels throughout house. 14) Missing air barriers in stairway & chase in bed 2 on front wall. 15) Nail osb in bed 2 to right of window. 16) Finish air barrier between tub & shower in master bathroom. 17) Need receptacle on back of house accessible

ADDRESS : 436 STONE CROSS DR SUBDIV: STONE CROSS
CONTRACTOR : AMERICAN HOMESMITH LLC PHONE : (919) 422-4128
OWNER : ODOM STEVEN C PHONE : (910) 257-3498
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

from grade.

PAY \$50 RE FEE

DO NOT INSULATE OR SIDE

R425 01 8/19/12 TI FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002279974
9-19-12 AP JD

COMMENTS AND NOTES

ADDRESS : 436 STONE CROSS DR
 CONTRACTOR : AMERICAN HOMESMITH LLC
 OWNER : ODOM STEVEN C
 PARCEL : 01-0535-02- -0100- -39-
 APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 06/20/2012 10:00 AM JBROCK ----
 HWY 210 FROM LILLINGTON TURN RIGTH ON
 OVERHILLS RD RIGHT INTO STONECROSS LOT
 70

SUBDIV: STONE CROSS
 PHONE : (919) 422-4128
 PHONE : (910) 257-3498

SCANNED

STRUCTURE: 000 000 51X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE DATE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/12	VC	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002257587
	7/27/12	CA	VOICE MESSAGE LEFT T/S: 07/27/2012 10:13 AM VBROWN ----- TRAVIS SENT EMAIL AT 9:26 CA INSP.
B101 02	7/31/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002258443
	7/31/12	AP	T/S: 07/30/2012 10:06 AM DJOHNSON -----
A814 01	8/10/12	TW	✓ ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002263499
	8/10/12	AP	436 STONE CROSS DR LOT 70 SPRING LAKE 28390----- T/S: 08/10/2012 03:02 PM TWARD -----
B103 01	8/10/12	FS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002263481
	8/10/12	CA	T/S: 08/10/2012 02:41 PM FSPIVEY -----
B103 02	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265825
	8/15/12	AP	-----
B105 01	8/27/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002271062
	8/27/12	AP	-----
E207 01	8/27/12	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002271054
	8/27/12	AP	-----
R427 01	9/17/12	TI	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002279297

9-17-12 op TJ

COMMENTS AND NOTES

ADDRESS : 436 STONE CROSS DR
CONTRACTOR : AMERICAN HOMESMITH LLC
OWNER : ODOM STEVEN C
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/20/2012 10:00 AM JBROCK ----
HWY 210 FROM LILLINGTON TURN RIGTH ON
OVERHILLS RD RIGHT INTO STONECROSS LOT
70

SUBDIV: STONE CROSS
PHONE : (919) 422-4128
PHONE : (910) 257-3498

STRUCTURE: 000 000 51X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/12	VC	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002257587
	7/27/12	CA	VOICE MESSAGE LEFT T/S: 07/27/2012 10:13 AM VBROWN ----- TRAVIS SENT EMAIL AT 9:26 CA INSP.
B101 02	7/31/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002258443
	7/31/12	AP	T/S: 07/30/2012 10:06 AM DJOHNSON -----
A814 01	8/10/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002263499
	8/10/12	AP	436 STONE CROSS DR LOT 70 SPRING LAKE 28390----- T/S: 08/10/2012 03:02 PM TWARD -----
B103 01	8/10/12	FS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002263481
	8/10/12	CA	T/S: 08/10/2012 02:41 PM FSPIVEY -----
B103 02	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265825
	8/15/12	AP	-----
B105 01	8/27/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002271062
	8/27/12	AP	-----
E207 01	8/27/12	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002271054
	8/27/12	AP	-----
R427 01	9/17/12	JH	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002279297
	9/17/12	DP	1) Fire caulk drain & water lines in garage on house wall @ top & bottom plate. 2) Nail all holes in structural nail plates @ top plate on drain lines in garage. 3) Missing lvl header over kitchen window per plans. 4) Seal all cracks in air barriers @ canilevers in kitchen, dining room & living room. 5) Nail osb on studs to right of kitchen window. 6) Fire caulk drain & water lines @ top & bottom plates in half bath. 7) Label dryer duct length per code. 8) Seal cracks in air barriers under stairs on garage wall. 9) Missing air barriers & insulation under landing @ bottom of stairs. 10) Missing stud in hall @ top of stairs @ spare bath tub. 11) Missing fire caulk on all plumbing @ top & bottom plate throughout house. 12) Fire caulk hole @ pipe for tub drain for spare bath. 13) Missing baffels throughout house. 14) Missing air barriers in stairway & chase in bed 2 on front wall. 15) Nail osb in bed 2 to right of window. 16) Finish air barrier between tub & shower in master bathroom. 17) Need receptacle on back of house accessible

PREPARED 9/18/12, 13:58:18
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 20
DATE 9/19/12

ADDRESS : 436 STONE CROSS DR
CONTRACTOR : AMERICAN HOMESMITH LLC
OWNER : ODOM STEVEN C
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)

SUBDIV: STONE CROSS
PHONE : (919) 422-4128
PHONE : (910) 257-3498

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

from grade.

PAY \$50 RE FEE

DO NOT INSULATE OR SIDE

R425 01 8/19/12 TI FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002279974

9-19-12

AP JD

----- COMMENTS AND NOTES -----

ADDRESS : 436 STONE CROSS DR SUBDIV: STONE CROSS
CONTRACTOR : AMERICAN HOMESMITH LLC PHONE : (919) 422-4128
OWNER : ODOM STEVEN C PHONE : (910) 257-3498
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 06/20/2012 10:00 AM JBROCK ----
HWY 210 FROM LILLINGTON TURN RIGTH ON
OVERHILLS RD RIGHT INTO STONECROSS LOT
70

STRUCTURE: 000 000 51X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC -- EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/12 7/27/12	VC CA	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002257587 VOICE MESSAGE LEFT T/S: 07/27/2012 10:13 AM VBROWN ----- TRAVIS SENT EMAIL AT 9:26 CA INSP.
B101 02	7/31/12 7/31/12	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002258443 T/S: 07/30/2012 10:06 AM DJOHNSON -----
A814 01	8/10/12 8/10/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002263499 436 STONE CROSS DR LOT 70 SPRING LAKE 28390----- T/S: 08/10/2012 03:02 PM TWARD -----
B103 01	8/10/12 8/10/12	FS CA	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002263481 T/S: 08/10/2012 02:41 PM FSPIVEY -----
B103 02	8/15/12 8/15/12	JH AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265825 -----
B105 01	8/27/12 8/27/12	JH AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002271062 -----
E207 01	8/27/12 8/27/12	JH AP	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002271054 -----
R427 01	9/17/12 9/17/12	JH DP	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002279297 1)Fire caulk drain & water lines in garage on house wall @ top & bottom plate.2)Nail all holes in structural nail plates @ top plate on drain lines in garage.3)Missing lvl header over kitchen window per plans.4)Seal all cracks in air barriers @ canilevers in kitchen, dining room & living room.5)Nail osb on studs to right of kitchen window.6)Fire caulk drain & water lines @ top & bottom plates in half bath.7)Label dryer duct length per code.8)Seal cracks in air barriers under stairs on garage wall.9)Missing air barriers & insulation under landing @ bottom of stairs.10)Missing stud in hall @ top of stairs @ spare bath tub.11)Missing fire caulk on all plumbing @ top & bottom plate throughout house.12)Fire caulk hole @ pipe for tub drain for spare bath.13)Missing baffels throughout house.14)Missing air barriers in stairway & chase in bed 2 on front wall.15)Nail osb in bed 2 to right of window.16)Finish air barrier between tub & shower in master -----

ADDRESS . . : 436 STONE CROSS DR SUBDIV: STONE CROSS
CONTRACTOR : AMERICAN HOMESMITH LLC PHONE : (919) 422-4128
OWNER . . . : ODOM STEVEN C PHONE : (910) 257-3498
PARCEL . . . : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			bathroom.17)Need receptacle on back of house accessible from grade. PAY \$50 RE FEE DO NOT INSULATE OR SIDE
R425 01	9/19/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002279974
	9/19/12	AP	-----
I129 01	9/21/12	JH	R*INSULATION INSPECTION VRU #: 002280962
	9/21/12	AP	-----
P307 01	9/28/12	TI	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002284651
	<i>9-28-12</i>	<i>ALJH</i>	

----- COMMENTS AND NOTES -----

ADDRESS : 436 STONE CROSS DR
CONTRACTOR : AMERICAN HOMESMITH LLC
OWNER : ODOM STEVEN C
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 06/20/2012 10:00 AM JBROCK ----
HWY 210 FROM LILLINGTON TURN RIGTH ON
OVERHILLS RD RIGHT INTO STONECROSS LOT
70

SUBDIV: STONE CROSS
PHONE : (919) 422-4128
PHONE : (910) 257-3498

STRUCTURE: 000 000 51X38 3BDR CRAWL W/ GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	7/27/12	VC	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002257587
	7/27/12	CA	VOICE MESSAGE LEFT T/S: 07/27/2012 10:13 AM VBROWN ---- TRAVIS SENT EMAIL AT 9:26 CA INSP.
B101 02	7/31/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002258443
	7/31/12	AP	T/S: 07/30/2012 10:06 AM DJOHNSON ----
A814 01	8/10/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002263499
	8/10/12	AP	436 STONE CROSS DR LOT 70 SPRING LAKE 28390---- T/S: 08/10/2012 03:02 PM TWARD ----
B103 01	8/10/12	FS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002263481
	8/10/12	CA	T/S: 08/10/2012 02:41 PM FSPIVEY ----
B103 02	8/15/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002265825
	8/15/12	AP	----
B105 01	8/27/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002271062
	8/27/12	AP	----
E207 01	8/27/12	JH	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002271054
	8/27/12	AP	----
R427 01	9/17/12	JH	FOUR TRADE ROUGH IN >2500 TIME: 17:00 VRU #: 002279297
	9/17/12	DP	1)Fire caulk drain & water lines in garage on house wall @ top & bottom plate.2)Nail all holes in structural nail plates @ top plate on drain lines in garage.3)Missing lvl header over kitchen window per plans.4)Seal all cracks in air barriers @ canilevers in kitchen, dining room & living room.5)Nail osb on studs to right of kitchen window.6)Fire caulk drain & water lines @ top & bottom plates in half bath.7)Label dryer duct length per code.8)Seal cracks in air barriers under stairs on garage wall.9)Missing air barriers & insulation under landing @ bottom of stairs.10)Missing stud in hall @ top of stairs @ spare bath tub.11)Missing fire caulk on all plumbing @ top & bottom plate throughout house.12)Fire caulk hole @ pipe for tub drain for spare bath.13)Missing baffels throughout house.14)Missing air barriers in stairway & chase in bed 2 on front wall.15)Nail osb in bed 2 to right of window.16)Finish air barrier between tub & shower in master bathroom.17)Need receptacle on back of house accessible

PREPARED 10/12/12, 14:13:19
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 13
DATE 10/15/12

ADDRESS : 436 STONE CROSS DR
CONTRACTOR : AMERICAN HOMESMITH LLC
OWNER : ODOM STEVEN C
PARCEL : 01-0535-02- -0100- -39-
APPL NUMBER: 12-50029211 CP NEW RESIDENTIAL (SFD)

SUBDIV: STONE CROSS
PHONE : (919) 422-4128
PHONE : (910) 257-3498

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			from grade. PAY \$50 RE FEE DO NOT INSULATE OR SIDE
R425 01	9/19/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002279974
	9/19/12	AP	
I129 01	9/21/12	JH	R*INSULATION INSPECTION VRU #: 002280962
	9/21/12	AP	
P307 01	9/28/12	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002284651
	9/28/12	AP	
E209 01	10/15/12	TI	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002291078
	<i>10-15-12</i>	<i>APJH</i>	

----- COMMENTS AND NOTES -----