

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Gary Robinson Homes LLC

Address: 17 Valor Cir

Date: 11-14-12

Building Official: James Hall

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

58668005-01

ADDRESS : 17 VALOR CIR SUBDIV: GWEN OAKS 63 LOTS  
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562  
 OWNER : 210 HIGHWAY DEVELOPMENT LLC PHONE :  
 PARCEL : 01-0547- -0024- -31-  
 APPL NUMBER: 12-50029285 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 07/04/2012 04:43 PM VBROWN ----  
 65 VALOR CIRCLE, GWEN OAKS SUB DIV #30.  
 210S, GWEN OAKS ON LEFT ON TATICAL DR,  
 RIGHT ON VALOR CIR. CIRCULAR DRIVE WAY  
 WITH ACCESS ON VALOR AND TATICAL.

STRUCTURE: 000 000 32X50 3BDR 2.5BATH SFD, GAR, CRWL, FINBONRM  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002265854
	8/15/12	AP	
B103 01	8/30/12	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002272839
	8/30/12	AP	
B105 01	9/04/12	JH	R*OPEN FLOOR VRU #: 002273654
	9/04/12	DA	Back girder the center of the girder is not in the center 1/3 of the piers
A814 01	9/04/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002273662
	8/31/12	AP	17 Valor cir lot 30 bunlevel 28323 T/S: 08/31/2012 05:15 PM TWARD
B105 02	9/05/12	DT	R*OPEN FLOOR VRU #: 002274082
	9/05/12	AP	T/S: 09/05/2012 11:07 AM DETAYLOR
R425 01	9/27/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002283711
	9/27/12	DA	1)Seal all holes & carcks in air barriers throughout house.2)Missing 2 studs in garage on back wall.3)Nail lvls every 12" per manufacture instructions.4)Duct for exhaust fan vent in half bath 14' max.5)Fire caulk holes in top & bottom plate in media room closet on end all.6)Missing air barrier in chase @ laundry room.7)Missing osb on corners of house.
I129 01	10/01/12	MR	R*INSULATION INSPECTION VRU #: 002284925
	10/01/12	AP	T/S: 10/01/2012 02:56 PM MREARIC
R425 02	10/01/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002285195
	10/01/12	AP	T/S: 10/01/2012 02:56 PM MREARIC
H824 01	10/23/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002295285
	10/23/12	AP	T/S: 10/24/2012 11:08 AM SSTEWARD T/S: 10/24/2012 11:08 AM SSTEWARD
E209 01	11/06/12	DT	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002299436
	11/07/12	AP	
R429 01	11/14/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002301984
	11-14-12	AP JH	T/S: 11/13/2012 10:54 AM VBROWN

COMMENTS AND NOTES

-----  
ADDRESS . : 17 VALOR CIR SUBDIV: GWEN OAKS 63 LOTS  
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562  
OWNER . . : 210 HIGHWAY DEVELOPMENT LLC PHONE :  
PARCEL . . : 01-0547- - -0024- -31-  
APPL NUMBER: 12-50029285 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 07/04/2012 04:43 PM VBROWN ----  
65 VALOR CIRCLE, GWEN OAKS SUB DIV #30.  
210S, GWEN OAKS ON LEFT ON TATICAL DR,  
RIGHT ON VALOR CIR. CIRCULAR DRIVE WAY  
WITH ACCESS ON VALOR AND TATICAL.  
-----

**STRUCTURE: 000 000 32X50 3BDR 2.5BATH SFD, GAR, CRWL, FINBONRM**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/15/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002265854
	8/15/12	AP	-----
B103 01	8/30/12	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002272839
	8/30/12	AP	-----
B105 01	9/04/12	JH	R*OPEN FLOOR VRU #: 002273654
	9/04/12	DA	Back girder the centerof the girder is not in the center 1/3 of the piers
A814 01	9/04/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002273662
	8/31/12	AP	17 Valor cir lot 30 bunnlevel 28323----- T/S: 08/31/2012 05:15 PM TWARD -----
B105 02	9/05/12	DT	R*OPEN FLOOR VRU #: 002274082
	9/05/12	AP	T/S: 09/05/2012 11:07 AM DETAYLOR -----
R425 01	9/27/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002283711
	9/27/12	DA	1)Seal all holes & carcks in air barriers throughout house.2)Missing 2 studs in garage on back wall.3)Nail lvls every 12" per manufacture instructions.4)Duct for exhaust fan vent in half bath 14' max.5)Fire caulk holes in top & bottom plate in media room closet on end all.6)Missing air barrier in chase @ laundry room.7)Missing osb on corners of house.
I129 01	10/01/12	MR	R*INSULATION INSPECTION VRU #: 002284925
	10/01/12	AP	T/S: 10/01/2012 02:56 PM MREARIC -----
R425 02	10/01/12	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002285195
	10/01/12	AP	T/S: 10/01/2012 02:56 PM MREARIC -----
H824 01	10/23/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002295285
	10/23/12	AP	T/S: 10/24/2012 11:08 AM SSTEWARD ----- T/S: 10/24/2012 11:08 AM SSTEWARD -----
E209 01	11/06/12	TI	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002299436
	11/16/12	AP DT	

----- COMMENTS AND NOTES -----