Department of Environment, Health and Natur sources
Division of Environmental Health
On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant:
Address: Date Evaluated:
Proposed Facility: 2 [illegible] Design Flow (.1949): 240 gpd Property Size:
Location of Site: Property Recorded:
Water Supply: ☒ Public ☐ Individual ☐ Well ☐ Spring ☐ Other
Evaluation Method: ☒ Auger Boring ☐ Pit ☐ Cut
Type of Wastewater: ☒ Sewage ☐ Industrial Process ☐ Mixed

PROFILE #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-28"	G S	VFR NS/NP					S .8
2		0-20"	G S	VFR NS/NP					
		20-38"	SBK SCL	FR NS/NP					PS .5
3		0-28"	G S	VFR NS/NP					S .8
4		0-24"	G S	VFR NS/NP					
		24-28"	SBK SCL	FR NS/NP					PS .5

Description	Initial System	Repair System
Available Space (.1945)	✓	✓
System Type(s)	2 SFD [illegible]	
Site LTAR	.5	.5

Other Factors (.1946):
Site Classification (.1948): PS
Evaluated By: [illegible]
Others Present:

FILE #

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8		
S-SHOULDER SLOPE		LS-LOAMY SAND		VFR-VERY FRIABLE	NS-NON-STICKY
L-LINEAR SLOPE				FR-FRIABLE	SS-SLIGHTY STICKY
FS-FOOT SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
N-NOSE SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
H-HEAD SLOPE				EFI-EXTREMELY FIRM	NP-NON-PLASTIC
CC-CONCLAVE SLOPE	III	SI-SILT	0.6 - 0.3		SP-SLIGHTLY STICKY
CV-CONVEX SLOPE		SIL-SILT LOAM			P-PLASTIC
T-TERRACE		CL-CLAY LOAM			VP-VERY PLASTIC
FP-FLOOD PLAN		SCL-SANDY CLAY LOAM			
	IV	SIC-SILTY CLAY	0.4 - 0.1		
		C-CLAY			
		SC-SANDY CLAY			

STRUCTURE	MINERALOGY
SG-SINGLE GRAIN	SLIGHTLY EXPANSIVE
M- MASSIVE	
CR-CRUMB	EXPANSIVE
GR-GRANULAR	
SBK-SUBANGULAR BLOCKY	
ABK-ANGULAR BLOCKY	
PL-PLATY	
PR-PRISMATIC	

Show profile locations and other site features (dimensions, references or benchmark, and North)

MICKEY R. BENNETT LAND SURVEYOR

MUNICIPALITY THAT HAS AN ORDINANCE THAT REGULATES PARCELS OF LAND

"WILL LUCAS RD." 60' R/W

EX.8" & 4" WATERMAINS

N 82°08'19"E 152.09' NMN

N 81°48'41"E 60.32' NMN

N 79°45'46"E 91.88'

N 76°21'34"E 124.98'

N 71°25'3 46.45'

30.00' NIS

30.00' NIS

30.04' NIS

SITE PLAN APPROVAL

DISTRICT RA2CR USE SFD

#BEDROOMS 2

7.5.12 djanwork

ZONING ADMINISTRATOR

DRIVE WAY

245'

2

1.40 AC.TOTAL

0.11 AC.R/W

1.29 AC.NET

3

1.41 AC.TOTAL

0.11 AC.R/W

1.30 AC.NET

4

1.53 AC.TOTAL

0.12 AC.R/W

1.41 AC.NET

S 07°21'58"E 399.63'

370.77'

400.77'

S 07°21'58"E

40'x50'

GARAGE

50'

110'

NIS 152.09'

152.09'

S 82°34'11"W 456.26'

NIS EDGE OF WOODS

S 07°21'58"E TOTAL 56.00'

EDGE OF WOODS

NIS

2010013694

TOSHIKO HIGO HERRING

DB 589,PG 180

PIN # 0534-85-7267.000

PARCEL ID # 01054 0011

104.45 AC.+ - RESIDUAL

FOR REGISTRATION REGISTER OF DEEDS
KIMBERLY S. HARGROVE
HARNETT COUNTY, NC
2010 SEP 24 12:56:44 PM
BK 2810 PG 696-697 FEE:$21.00

Beach Homes Inc.
Lot 3 Will Lucas Rd.

DEED REFERENCE