

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Gary Robinson Homes LLC

Address: 43 Tactical Dr

Date: 1-29-13

Building Official: _____

James T Hall

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

80468095-01

ADDRESS : 43 TACTICAL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : PARADISE HOMES
 PARCEL : 01-0547- -0024- -03-
 APPL NUMBER: 12-50029408 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/12/2012 06:36 PM VBROWN ----
 TACTICAL DRIVE, GWEN OAKS SUB DIV #3.
 210S, LEFT INTO GWEN OAKS SUB DIV.

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 46X50 4BDR 2.5 SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4.00
 SEPTIC - EXISTING? : NEW TANK
 PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/26/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283273
	9/26/12	DA	Remove all of stump in footing on garage back wall-----
B101 02	9/27/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283772
	9/27/12	AP	
A814 01	10/09/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002288348
	10/10/12	AP	43 TACTICAL DR LOT 3 BUNNLEVEL 28323----- T/S: 10/10/2012 04:24 PM TWARD -----
B103 01	10/09/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002288322
	10/09/12	AP	
B105 01	10/11/12	JH	R*OPEN FLOOR VRU #: 002289544
	10/11/12	AP	
R425 01	11/01/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002298057
	11/01/12	DA	No plans on site -----
R425 02	11/05/12	MR	FOUR TRADE ROUGH IN VRU #: 002298743
	11/05/12	DA	T/S: 11/05/2012 01:05 PM MREARIC ----- outlet needed left side of fireplace / large truss hanger over bedroom needs nails / no plumbing tests are ready
R425 03	11/06/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002299600
	11/07/12	DA	T/S: 11/05/2012 10:37 AM VBROWN ----- T/S: 11/07/2012 08:31 AM DETAYLOR ----- Need engineer repair for floor truss bored for plumbing Okay to side and insulate
I129 01	11/09/12	DT	R*INSULATION INSPECTION VRU #: 002301141
	11/09/12	AP	T/S: 11/09/2012 12:27 PM DETAYLOR -----
R425 04	11/09/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002301414
	11/09/12	AP	T/S: 11/08/2012 02:13 PM DJOHNSON ----- WHEN SCHEDULING AN INSULATION INSPECTION MAKE SURE THE ROUGH IN IS ALSO SCHEDULED IF IT FAILED AT ROUGH IN. OTHERWISE THE INSULATION WILL BE CANCELLED. T/S: 11/09/2012 12:27 PM DETAYLOR -----
H824 01	12/19/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002320208
	12/19/12	AP	T/S: 12/21/2012 11:57 AM SSTEWARD ----- T/S: 12/21/2012 11:57 AM SSTEWARD -----
R429 01	1/18/13	TI	FOUR TRADE FINAL VRU #: 002328557
	1/17/13	CA	
R429 02	1/22/13	JH	FOUR TRADE FINAL VRU #: 002328805
	1/22/13	CA	T/S: 01/22/2013 09:22 AM DJOHNSON ----- CANCELLED PER JIMMY CUSTOMER NOT READY FOR FINAL WILL

PREPARED 1/28/13, 13:57:46
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 12
DATE 1/29/13

ADDRESS : 43 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : PARADISE HOMES PHONE :
PARCEL : 01-0547- - -0024- -03-
APPL NUMBER: 12-50029408 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
			SCHEDULE TEMPORARY POWER
E209 01	1/22/13	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002329829
	1/22/13	AP	T/S: 01/22/2013 09:24 AM DJOHNSON -----
R429 03	1/29/13	TI	FOUR TRADE FINAL VRU #: 002332047
	<i>1-29-13 AP JH</i>		Please call me with the time you will be at the property and I will meet you there. Thanks Gary W. Robinson 9109772562

COMMENTS AND NOTES

ADDRESS . . : 43 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . . : PARADISE HOMES
PARCEL . . . : 01-0547- - -0024- -03-
APPL NUMBER: 12-50029408 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/12/2012 06:36 PM VBROWN -----
TACTICAL DRIVE, GWEN OAKS SUB DIV #3.
210S, LEFT INTO GWEN OAKS SUB DIV.

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

STRUCTURE: 000 000 46X50 4BDR 2.5 SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 4.00
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/26/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283273
	9/26/12	DA	Remove all of stump in footing on garage back wall-----
B101 02	9/27/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283772
	9/27/12	AP	
A814 01	10/09/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002288348
	10/10/12	AP	43 TACTICAL DR LOT 3 BUNNLEVEL 28323----- T/S: 10/10/2012 04:24 PM TWARD -----
B103 01	10/09/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002288322
	10/09/12	AP	
B105 01	10/11/12	JH	R*OPEN FLOOR VRU #: 002289544
	10/11/12	AP	
R425 01	11/01/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002298057
	11/01/12	DA	No plans on site -----
R425 02	11/05/12	TI	FOUR TRADE ROUGH IN VRU #: 002298743

11-5-12 DA-MR

----- COMMENTS AND NOTES -----

HARNETT COUNTY

**Building Inspections Dept.
108 E. Front St.
Lillington, NC 27546
910-893-7525**

DATE: 11/05/2012

PERMIT # 12-50029408

ADDRESS: 43 tactical

- 1. Outlet needed in living room on left side of fireplace**
- 2. Large "jg26" hanger is missing nails over front bedroom**
- 3. No water in any pipes for plumbing tests, or pressure**

Mike Rearic cell# (910) 984- 4772

ADDRESS : 43 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER : PARADISE HOMES PHONE :
PARCEL : 01-0547- - -0024- -03-
APPL NUMBER: 12-50029408 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 08/12/2012 06:36 PM VBROWN ----
TACTICAL DRIVE, GWEN OAKS SUB DIV #3.
210S, LEFT INTO GWEN OAKS SUB DIV.

STRUCTURE: 000 000 46X50 4BDR 2.5 SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/26/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283273
	9/26/12	DA	Remove all of stump in footing on garage back wall-----
B101 02	9/27/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283772
	9/27/12	AP	-----
A814 01	10/09/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002288348
	10/10/12	AP	43 TACTICAL DR LOT 3 BUNNLEVEL 28323----- T/S: 10/10/2012 04:24 PM TWARD -----
B103 01	10/09/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002288322
	10/09/12	AP	-----
B105 01	10/11/12	JH	R*OPEN FLOOR VRU #: 002289544
	10/11/12	AP	-----
R425 01	11/01/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002298057
	11/01/12	DA	No plans on site -----
R425 02	11/05/12	MR	FOUR TRADE ROUGH IN VRU #: 002298743
	11/05/12	DA	T/S: 11/05/2012 01:05 PM MREARIC ----- outlet needed left side of fireplace / large truss hanger over bedroom needs nails / no plumbing tests are ready
R425 03	11/06/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002299600
	11/07/12	DA	T/S: 11/05/2012 10:37 AM VBROWN ----- T/S: 11/07/2012 08:31 AM DETAYLOR ----- Need engineer repair for floor truss bored for plumbing Okay to side and insulate
I129 01	11/09/12	DT	R*INSULATION INSPECTION VRU #: 002301141
	11/09/12	AP	T/S: 11/09/2012 12:27 PM DETAYLOR -----
R425 04	11/09/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002301414
	11/09/12	AP	T/S: 11/08/2012 02:13 PM DJOHNSON ----- WHEN SCHEDULING AN INSULATION INSPECTION MAKE SURE THE ROUGH IN IS ALSO SCHEDULED IF IT FAILED AT ROUGH IN. OTHERWISE THE INSULATION WILL BE CANCELLED. T/S: 11/09/2012 12:27 PM DETAYLOR -----
H824 01	12/19/12	OT	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002320208
	12/19/12	AP	T/S: 12/21/2012 11:57 AM SSTEWARD ----- T/S: 12/21/2012 11:57 AM SSTEWARD -----
R429 01	1/18/13	TI	FOUR TRADE FINAL VRU #: 002328557
	1/17/13	CA	
R429 02	1/22/13	JH	FOUR TRADE FINAL VRU #: 002328805
	1/22/13	CA	T/S: 01/22/2013 09:22 AM DJOHNSON -----

CONTINUED ONTO NEXT PAGE

PREPARED 1/22/13, 9:24:42
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 2
DATE 1/22/13

ADDRESS . : 43 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . : PARADISE HOMES
PARCEL . . : 01-0547- - -0024- -03-
APPL NUMBER: 12-50029408 CP NEW RESIDENTIAL (SFD)

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

REQUESTED INSP DESCRIPTION
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS

CANCELLED PER JIMMY CUSTOMER NOT READY FOR FINAL WILL
SCHEDULE TEMPORARY POWER
E209 01 1/22/13 TI R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002329829
1-22-13 ALJA T/S: 01/22/2013 09:24 AM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS . . : 43 TACTICAL DR
CONTRACTOR : GARY ROBINSON HOMES LLC
OWNER . . . : PARADISE HOMES
PARCEL . . . : 01-0547- - -0024- -03-
APPL NUMBER: 12-50029408 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 08/12/2012 06:36 PM VBROWN -----
TACTICAL DRIVE, GWEN OAKS SUB DIV #3.
210S, LEFT INTO GWEN OAKS SUB DIV.

SUBDIV: GWEN OAKS 63 LOTS
PHONE : (910) 977-2562
PHONE :

STRUCTURE: 000 000 46X50 4BDR 2.5 SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4.00
SEPTIC - EXISTING? : NEW TANK
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/26/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283273
	9/26/12	DA	Remove all of stump in footing on garage back wall-----
B101 02	9/27/12	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002283772
	9/27/12	AP	
A814 01	10/09/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002288348
	10/10/12	AP	43 TACTICAL DR LOT 3 BUNNLEVEL 28323----- T/S: 10/10/2012 04:24 PM TWARD -----
B103 01	10/09/12	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002288322
	10/09/12	AP	
B105 01	10/11/12	JH	R*OPEN FLOOR VRU #: 002289544
	10/11/12	AP	
R425 01	11/01/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002298057
	11/01/12	DA	No plans on site
R425 02	11/05/12	MR	FOUR TRADE ROUGH IN VRU #: 002298743
	11/05/12	DA	T/S: 11/05/2012 01:05 PM MREARIC ----- outlet needed left side of fireplace / large truss hanger over bedroom needs nails / no plumbing tests are ready
R425 03	11/06/12	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002299600
	11/6/12	DA JJ	T/S: 11/05/2012 10:37 AM VBROWN -----

----- COMMENTS AND NOTES -----