

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Gary Robinson Homes LLC

Address: 154 Tactical Dr

Date: 1-29-13

Building Official: James T Hall

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

607468005-01
1P-500-d1

ADDRESS : 154 TACTICAL DR
 CONTRACTOR : GARY ROBINSON HOMES LLC
 OWNER : PARADISE HOMES
 PARCEL : 01-0547- - -0024- -46-
 APPL NUMBER: 12-50029409 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/12/2012 06:39 PM VBROWN ----
 TACTICAL DRIVE, GWEN OAKS SUB DIV #46
 210S, LEFT INTO GWN OAKS SUB DIV.
 premise #06230693

SUBDIV: GWEN OAKS 63 LOTS
 PHONE : (910) 977-2562
 PHONE :

STRUCTURE: 000 000 42X46 3BDR 2.5BATH SFD W GAR CRAWL
 FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 3.00
 SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/05/12	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002287288
	10/05/12	AP	T/S: 10/05/2012 12:59 PM MREARIC
B103 01	10/17/12	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002291813
	10/17/12	AP	T/S: 10/17/2012 10:17 AM DETAYLOR
A814 01	10/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002291821
	10/24/12	AP	154 tactical dr lot 46 bunnlevel 28323
B105 01	10/19/12	DT	T/S: 10/24/2012 03:46 PM TWARD
	10/19/12	CA	R*OPEN FLOOR VRU #: 002293090
B105 02	10/23/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002294023
	10/23/12	AP	
R425 01	11/09/12	DT	FOUR TRADE ROUGH IN VRU #: 002301133
	11/09/12	DA	T/S: 11/09/2012 12:28 PM DETAYLOR No test on drain lines b trusses missing web braces Fire caulk hole in top plate at bonus room Okay to side and insulate
I129 01	11/13/12	JH	R*INSULATION INSPECTION VRU #: 002301992
	11/13/12	AP	
R425 02	11/13/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002302073
	11/13/12	AP	
H824 01	12/19/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002320190
	12/19/12	AP	T/S: 12/21/2012 11:55 AM SSTEWARD T/S: 12/21/2012 11:55 AM SSTEWARD
R429 01	1/22/13	JH	FOUR TRADE FINAL VRU #: 002328540
	1/22/13	CA	T/S: 01/22/2013 09:21 AM DJOHNSON CANCELLED PER JIMMY CUSTOMER NOT READY FOR FINAL WILL SCHEDULE TEMPORARY POWER
E209 01	1/22/13	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002329811
	1/22/13	AP	T/S: 01/22/2013 09:23 AM DJOHNSON
R429 02	1/29/13	TI	FOUR TRADE FINAL VRU #: 002332039
	1-29-13	AP/IV	Please let me know what time you will be there for the inspection and I will meet you. Thanks Gary W. Robinson 910-977-2562

COMMENTS AND NOTES

ADDRESS . . : 154 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER . . : PARADISE HOMES PHONE :
 PARCEL . . : 01-0547- - -0024- -46-
 APPL NUMBER: 12-50029409 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/12/2012 06:39 PM VBROWN -----
 TACTICAL DRIVE, GWEN OAKS SUB DIV #46
 210S, LEFT INTO GWN OAKS SUB DIV.
 premise #06230693

STRUCTURE: 000 000 42X46 3BDR 2.5BATH SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/05/12	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002287288
	10/05/12	AP	T/S: 10/05/2012 12:59 PM MREARIC -----
B103 01	10/17/12	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002291813
	10/17/12	AP	T/S: 10/17/2012 10:17 AM DETAYLOR -----
A814 01	10/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002291821
	10/24/12	AP	154 tactical dr lot 46 bunnlevel 28323----- T/S: 10/24/2012 03:46 PM TWARD -----
B105 01	10/19/12	DT	R*OPEN FLOOR VRU #: 002293090
	10/19/12	CA	
B105 02	10/23/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002294023
	10/23/12	AP	-----
R425 01	11/09/12	TI	FOUR TRADE ROUGH IN VRU #: 002301133

11/9/12 DAD

----- COMMENTS AND NOTES -----

ADDRESS . : 154 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . : PARADISE HOMES PHONE :
PARCEL . . : 01-0547- - -0024- -46-
APPL NUMBER: 12-50029409 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 08/12/2012 06:39 PM VBROWN ----
TACTICAL DRIVE, GWEN OAKS SUB DIV #46
210S, LEFT INTO GWN OAKS SUB DIV.
premise #06230693

STRUCTURE: 000 000 42X46 3BDR 2.5BATH SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/05/12	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002287288
	10/05/12	AP	T/S: 10/05/2012 12:59 PM MREARIC -----
B103 01	10/17/12	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002291813
	10/17/12	AP	T/S: 10/17/2012 10:17 AM DETAYLOR -----
A814 01	10/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002291821
	10/24/12	AP	154 tactical dr lot 46 bunnlevel 28323----- T/S: 10/24/2012 03:46 PM TWARD -----
B105 01	10/19/12	DT	R*OPEN FLOOR VRU #: 002293090
	10/19/12	CA	
B105 02	10/23/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002294023
	10/23/12	AP	
R425 01	11/09/12	DT	FOUR TRADE ROUGH IN VRU #: 002301133
	11/09/12	DA	T/S: 11/09/2012 12:28 PM DETAYLOR ----- No test on drain lines Trusses missing web braces Fire caulk hole in top plate at bonus room okay to side and insulate
I129 01	11/13/12	TI	R*INSULATION INSPECTION VRU #: 002301992
	<u>11-13-12</u>	<u>AP JW</u>	
R425 02	11/13/12	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002302073
	<u>11-13-12</u>	<u>AP JW</u>	

----- COMMENTS AND NOTES -----

ADDRESS : 154 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
 CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
 OWNER : PARADISE HOMES PHONE :
 PARCEL : 01-0547- - -0024- -46-
 APPL NUMBER: 12-50029409 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 08/12/2012 06:39 PM VBROWN ----
 TACTICAL DRIVE, GWEN OAKS SUB DIV #46
 210S, LEFT INTO GWN OAKS SUB DIV.
 premise #06230693

STRUCTURE: 000 000 42X46 3BDR 2.5BATH SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/05/12	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002287288
	10/05/12	AP	T/S: 10/05/2012 12:59 PM MREARIC -----
B103 01	10/17/12	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002291813
	10/17/12	AP	T/S: 10/17/2012 10:17 AM DETAYLOR -----
A814 01	10/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002291821
	10/24/12		154 Tactical Drive, Harnett County, NC 28323 T/S: 10/24/2012 03:46 PM TWARD -----
B105 01	10/19/12	DT	R*OPEN FLOOR VRU #: 002293090
	10/19/12	CA	
B105 02	10/23/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002294023
	10/23/12	AP	
R425 01	11/09/12	DT	FOUR TRADE ROUGH IN VRU #: 002301133
	11/09/12	DA	T/S: 11/09/2012 12:28 PM DETAYLOR ----- No test on drain lines b trusses missing web braces Fire caulk hole in top plate at bonus room Okay to side and insulate
I129 01	11/13/12	JH	R*INSULATION INSPECTION VRU #: 002301992
	11/13/12	AP	
R425 02	11/13/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002302073
	11/13/12	AP	
H824 01	12/19/12	OT	HARNETT COUNTY PERMIT TIME: 17:00 VRU #: 002320190
	12/19/12		T/S: 12/21/2012 11:55 AM SSTEWARD ----- T/S: 12/21/2012 11:55 AM SSTEWARD -----
R429 01	1/22/13	TI	FOUR TRADE FINAL VRU #: 002328540

Temp power
 COMMENTS AND NOTES

Trash

ADDRESS . . : 154 TACTICAL DR SUBDIV: GWEN OAKS 63 LOTS
CONTRACTOR : GARY ROBINSON HOMES LLC PHONE : (910) 977-2562
OWNER . . : PARADISE HOMES PHONE :
PARCEL . . : 01-0547- - -0024- -46-
APPL NUMBER: 12-50029409 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 08/12/2012 06:39 PM VBROWN ----
TACTICAL DRIVE, GWEN OAKS SUB DIV #46
210S, LEFT INTO GWN OAKS SUB DIV.
premise #06230693

STRUCTURE: 000 000 42X46 3BDR 2.5BATH SFD W GAR CRAWL

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/05/12	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002287288
	10/05/12	AP	T/S: 10/05/2012 12:59 PM MREARIC -----
B103 01	10/17/12	DT	R*BLDG FOUND & TEMP SVC POLE VRU #: 002291813
	10/17/12	AP	T/S: 10/17/2012 10:17 AM DETAYLOR -----
A814 01	10/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002291821
	10/24/12	AP	154 tactical dr lot 46 bunnlevel 28323----- T/S: 10/24/2012 03:46 PM TWARD -----
B105 01	10/19/12	DT	R*OPEN FLOOR VRU #: 002293090
	10/19/12	CA	
B105 02	10/23/12	JH	R*OPEN FLOOR TIME: 17:00 VRU #: 002294023
	10/23/12	AP	-----
R425 01	11/09/12	DT	FOUR TRADE ROUGH IN VRU #: 002301133
	11/09/12	DA	T/S: 11/09/2012 12:28 PM DETAYLOR ----- No test on drain lines b trusses missing web braces Fire caulk hole in top plate at bonus room Okay to side and insulate
I129 01	11/13/12	JH	R*INSULATION INSPECTION VRU #: 002301992
	11/13/12	AP	-----
R425 02	11/13/12	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002302073
	11/13/12	AP	-----
H824 01	12/19/12	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002320190
	12/19/12	AP	T/S: 12/21/2012 11:55 AM SSTEWARD ----- T/S: 12/21/2012 11:55 AM SSTEWARD -----
R429 01	1/22/13	JH	FOUR TRADE FINAL VRU #: 002328540
	1/22/13	CA	T/S: 01/22/2013 09:21 AM DJOHNSON ----- CANCELLED PER JIMMY CUSTOMER NOT READY FOR FINAL WILL SCHEDULE TEMPORARY POWER
E209 01	1/22/13	TI	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002329811
	<u>1-22-13</u>	<u>APTH</u>	T/S: 01/22/2013 09:23 AM DJOHNSON -----

----- COMMENTS AND NOTES -----