

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: L8605 Design Flow (.1949): 120 gpd Property Size:
 Location of Site: 3 Property Recorded: 360 JPI
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-24	FS	VF/NS/MP					
		24-36"	SBX SCL	R2 SS/SF	10YR2/7kR33"				P3 5
2		0"	SBX SCL		CR2 @ 17"				
3		0"	SBX SCL		CR2 @ 12"				
2,		0"	SBX SCL		CR2 @ 14"				
SEE PROPOSAL FROM SSE FOR NEW SYSTEM AREA									
w/ TYPICAL SOIL PROFILE									

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>P3</u> Evaluated By: <u>CS</u> Others Present: <u>BM</u>
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>AS (1945)</u>	<u>DRP</u>	
Site LTAR	<u>.3</u>	<u>.3</u>	

SEE PROPOSAL