

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: V Home

Name: CUMBERLAND HOMES

Address: 2245 SPRING FLOWERS
CAMERON 28325

Date: 12-14-12

Building Official: [Signature]

Permit Numbers

Building: _____
Electrical: _____
Insulation: _____
Plumbing: _____
Mechanical: 9-6-29A B
MFG Home: _____

ADDRESS : 240 SPRING FLOWERS DR SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 CONTRACTOR : CUMBERLAND HOMES INC PHONE : (910) 892-4345
 OWNER : CRESTVIEW DEVELOPMENT LLC PHONE :
 PARCEL : 09-9567-02- -0006- -21-
 APPL NUMBER: 12-50029413 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/19/2012 11:03 AM MTALBOTT --
 TAKE 27W TURN R ON JOHNSONVILLE SCHOOL
 RD TURN R ON PONDEROSA RD TURN R ON
 FERN RIDGE TURN R ON GREEN LINKS DR
 TURN L ON SPRING FLOWERS DR LOT ON R
 CAROLINA SEASONS LOT 22

STRUCTURE: 000 000 44X50 3BR ATT GARAGE DECK PATIO MONO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/14/12	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002264873
	8/15/12	AP	T/S: 08/15/2012 04:32 PM FSPIVEY -----
A814 01	8/29/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002272268
	8/31/12	AP	240 SPRING FLOWERS DR LOT 22 CAMERON 28326----- T/S: 08/31/2012 03:53 PM TWARD -----
P309 01	8/29/12	FS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002272250
	8/29/12	AP	T/S: 08/29/2012 02:41 PM FSPIVEY -----
B111 01	8/31/12	FS	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002272953
	8/31/12	DA	T/S: 08/29/2012 03:32 PM VBROWN ----- T/S: 08/31/2012 03:03 PM FSPIVEY ----- not ready
B111 02	9/05/12	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002274390
	9/05/12	AP	T/S: 09/05/2012 02:50 PM FSPIVEY -----
R425 01	10/16/12	FS	FOUR TRADE ROUGH IN VRU #: 002291264
	10/16/12	AP	T/S: 10/16/2012 02:06 PM FSPIVEY -----
I129 01	10/19/12	FS	R*INSULATION INSPECTION VRU #: 002292664
	10/19/12	AP	T/S: 10/19/2012 03:01 PM FSPIVEY -----
H824 01	11/13/12	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002303444
	11/13/12	AP	T/S: 11/14/2012 11:36 AM SSTEWARD ----- T/S: 11/14/2012 11:37 AM SSTEWARD -----
R429 01	12/12/12	MR	FOUR TRADE FINAL VRU #: 002315024
	12/12/12	DP	T/S: 12/12/2012 01:56 PM MREARIC ----- no jacuzzi / no jacuzzi access / either wire the float switch on the air handler or install a drain line
R429 02	12/14/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002316388

12-14-12
[Signature]

COMMENTS AND NOTES

[Handwritten signature]

ADDRESS : 240 SPRING FLOWERS DR
 CONTRACTOR : CUMBERLAND HOMES INC
 OWNER : CRESTVIEW DEVELOPMENT LLC
 PARCEL : 09-9567-02- -0006- -21-
 APPL NUMBER: 12-50029413 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 07/19/2012 11:03 AM MTALBOTT --
 TAKE 27W TURN R ON JOHNSONVILLE SCHOOL
 RD TURN R ON PONDEROSA RD TURN R ON
 FERN RIDGE TURN R ON GREEN LINKS DR
 TURN L ON SPRING FLOWERS DR LOT ON R
 CAROLINA SEASONS LOT 22

SUBDIV: CAROLINA SEASONS PH 2 80LOTS
 PHONE : (910) 892-4345
 PHONE :

STRUCTURE: 000 000 44X50 3BR ATT GARAGE DECK PATIO MONO

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/14/12	FS	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002264873
	8/15/12	AP	T/S: 08/15/2012 04:32 PM FSPIVEY -----
A814 01	8/29/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002272268
	8/31/12	AP	240 SPRING FLOWERS DR LOT 22 CAMERON 28326----- T/S: 08/31/2012 03:53 PM TWARD -----
P309 01	8/29/12	FS	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002272250
	8/29/12	AP	T/S: 08/29/2012 02:41 PM FSPIVEY -----
B111 01	8/31/12	FS	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002272953
	8/31/12	DA	T/S: 08/29/2012 03:32 PM VBROWN ----- T/S: 08/31/2012 03:03 PM FSPIVEY ----- not ready
B111 02	9/05/12	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002274390
	9/05/12	AP	T/S: 09/05/2012 02:50 PM FSPIVEY -----
R425 01	10/16/12	FS	FOUR TRADE ROUGH IN VRU #: 002291264
	10/16/12	AP	T/S: 10/16/2012 02:06 PM FSPIVEY -----
I129 01	10/19/12	FS	R*INSULATION INSPECTION VRU #: 002292664
	10/19/12	AP	T/S: 10/19/2012 03:01 PM FSPIVEY -----
H824 01	11/13/12	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002303444
	11/13/12	AP	T/S: 11/14/2012 11:36 AM SSTEWARD ----- T/S: 11/14/2012 11:37 AM SSTEWARD -----
R429 01	12/12/12	TI	FOUR TRADE FINAL VRU #: 002315024

12-12-12 DP-MR

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 12/12/2012

PERMIT # 12-50029413

ADDRESS: 240 spring flowers dr..

1. No Jacuzzi GFI
2. No Jacuzzi access
3. Either wire the float switch on the air handler or install a drain

50⁰⁰

4. outside A/c to be bigger

Mike Rearic cell# (910) 984- 4772