

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: LM Langdon

Address: 168 Old Stage N.

Date: 12-10-12

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: N \_\_\_\_\_

MFG Home: \_\_\_\_\_

*0025486*

Building Official: Ke Slatt

-----  
 ADDRESS : 168 OLD STAGE RD N SUBDIV:  
 CONTRACTOR : LANGDON L.M. PHONE : (919) 422-6946  
 OWNER : YOUNG BERNARD F & WIFE PHONE : (919) 639-2934  
 PARCEL : 07-0680- - -0153- -06-  
 APPL NUMBER: 12-50029486 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 08/01/2012 01:28 PM JBROCK ----  
 210 EAST TO SHERIFF JOHNSTON RD TO OLD  
 STAGE RD TURN R HOUSE ON THE LEFT LOT 2  
 -----

**STRUCTURE: 000 000 76.8X45.6 3BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
 -----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/12	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002269744
	8/23/12	AP	T/S: 08/22/2012 01:27 PM VBROWN ----- T/S: 08/23/2012 02:53 PM KSLATTUM -----
A814 01	8/31/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002273092
	8/31/12	AP	T/S: 08/30/2012 09:13 AM VBROWN ----- 168 OLD STAGE RD N LOT 2 LILLINGTON 27546-- .3S: 08/31/2012 04:05 PM TWARD -----
B103 01	8/31/12	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002273084
	8/31/12	AP	T/S: 08/30/2012 09:13 AM VBROWN ----- T/S: August 31, 2012 11:30 AM BSUTTON ----- There is no tpole on this jobsite
B105 01	9/14/12	KS	R*OPEN FLOOR TIME: 17:00 VRU #: 002278133
	9/14/12	AP	T/S: 09/13/2012 09:24 AM VBROWN ----- T/S: 09/14/2012 10:08 AM KSLATTUM -----
R425 01	10/01/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002284677
	10/01/12	DA	T/S: 09/27/2012 04:14 PM VBROWN ----- T/S: 10/01/2012 12:57 PM DETAYLOR ----- Sealed air barriers required for master and front bedroom between vaulted ceiling gable and attic Need fire caulk for electrical at top plate by master tub T1, T2, and ST1 trusses missing web braces, see docs ST1 trusses need 2 hurricane straps at front wall Okay to side and insulate
I129 01	10/04/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002286235
	10/04/12	AP	T/S: 10/02/2012 03:06 PM VBROWN ----- T/S: 10/04/2012 09:18 AM KSLATTUM -----
R425 02	10/04/12	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002286227
	10/04/12	AP	T/S: 10/02/2012 03:06 PM VBROWN ----- T/S: 10/04/2012 09:18 AM KSLATTUM -----
H824 01	10/23/12	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002295350
	10/23/12	AP	T/S: 10/24/2012 11:17 AM SSTEWARD ----- T/S: 10/24/2012 11:18 AM SSTEWARD -----
R429 01	12/03/12	KS	FOUR TRADE FINAL TIME: 17:00 VRU #: 002310753
	12/03/12	DA	T/S: 11/30/2012 01:35 PM DJOHNSON ----- T/S: 12/03/2012 09:02 AM KSLATTUM ----- Electrical panel sealed shut. You cannot have any obstructions to opening the panel. 2. Top step to get into house from garage cannot exceed 8 1/4 inches to top of

PREPARED 12/07/12, 14:05:20  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 18  
DATE 12/10/12

-----  
ADDRESS . . : 168 OLD STAGE RD N  
CONTRACTOR : LANGDON L.M.  
OWNER . . . : YOUNG BERNARD F & WIFE  
PARCEL . . . : 07-0680- - -0153- -06-  
APPL NUMBER: 12-50029486 CP NEW RESIDENTIAL (SFD)

SUBDIV:  
PHONE : (919) 422-6946  
PHONE : (919) 639-2934

-----  
REQUESTED INSP DESCRIPTION  
TYP/SQ COMPLETED RESULT RESULTS/COMMENTS  
-----  
R429 02 12/10/12 TI threshold 3. Need energy certificate with duct test and  
12-10 AP energy requirements.  
FOUR TRADE FINAL TIME: 17:00 VRU #: 002314052  
KEY UNDER 5 GALLON BUCKET ON FRONT PORCH

----- COMMENTS AND NOTES -----

ADDRESS : 168 OLD STAGE RD N SUBDIV:  
 CONTRACTOR : LANGDON L.M. PHONE : (919) 422-6946  
 OWNER : YOUNG BERNARD F & WIFE PHONE : (919) 639-2934  
 PARCEL : 07-0680- - -0153- -06-  
 APPL NUMBER: 12-50029486 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 08/01/2012 01:28 PM JBROCK ----  
 210 EAST TO SHERIFF JOHNSTON RD TO OLD  
 STAGE RD TURN R HOUSE ON THE LEFT LOT 2

**STRUCTURE: 000 000 76.8X45.6 3BDR CRAWL W/ GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	8/23/12	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002269744
	8/23/12	AP	T/S: 08/22/2012 01:27 PM VBROWN ----- T/S: 08/23/2012 02:53 PM KSLATTUM -----
A814 01	8/31/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002273092
	8/31/12	AP	T/S: 08/30/2012 09:13 AM VBROWN ----- 168 OLD STAGE RD N LOT 2 LILLINGTON 27546-- .3S: 08/31/2012 04:05 PM TWARD -----
B103 01	8/31/12	BS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002273084
	8/31/12	AP	T/S: 08/30/2012 09:13 AM VBROWN ----- T/S: August 31, 2012 11:30 AM BSUTTON ----- There is no tpole on this jobsite
B105 01	9/14/12	KS	R*OPEN FLOOR TIME: 17:00 VRU #: 002278133
	9/14/12	AP	T/S: 09/13/2012 09:24 AM VBROWN ----- T/S: 09/14/2012 10:08 AM KSLATTUM -----
R425 01	10/01/12	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002284677
	10/01/12	DA	T/S: 09/27/2012 04:14 PM VBROWN ----- T/S: 10/01/2012 12:57 PM DETAYLOR ----- Sealed air barriers required for master and front bedroom between vaulted ceiling gable and attic Need fire caulk for electrical at top plate by master tub T1, T2, and ST1 trusses missing web braces, see docs ST1 trusses need 2 hurricane straps at front wall Okay to side and insulate
I129 01	10/04/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002286235
	10/04/12	AP	T/S: 10/02/2012 03:06 PM VBROWN ----- T/S: 10/04/2012 09:18 AM KSLATTUM -----
R425 02	10/04/12	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002286227
	10/04/12	AP	T/S: 10/02/2012 03:06 PM VBROWN ----- T/S: 10/04/2012 09:18 AM KSLATTUM -----
H824 01	10/23/12	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002295350
	10/23/12	AP	T/S: 10/24/2012 11:17 AM SSTEWARD ----- T/S: 10/24/2012 11:18 AM SSTEWARD -----
R429 01	12/03/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002310753
	<u>12-3-12</u>	<u>DA</u>	T/S: 11/30/2012 01:35 PM DJOHNSON -----

COMMENTS AND NOTES