

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 8/22/12
 Proposed Facility: 4 Bedrooms Design Flow (.1949): 480 GPD Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 2-5%	0-48"	GS	VF2 NS/HP					S .8
2		0-6"	GS	VF2 NS/HP					
		6-36"	SBK C	F2 SS/SP	10YR 7/2 @ 30"				P5 .4
3		0-48"	GS	VF2 NS/HP					S .8
4		0-24"	GS	VF2 NS/HP					
		24-32"	SBK SL	F2 SS/SP					P5 .5
5		0-30"	GS	VF2 NS/HP					
		30-48"	GS L	VF2 NS/HP					S .6

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1945)	✓	✓	
System Type(s)	25" x 26"	25" x 26"	
Site LTAR	.6	.5	