

**County of Harnett**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance: \_\_\_\_\_ Occupancy: X**

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

**Permit Numbers**

Name: Lutie T Murphy

Building: 12-50029561

Electrical: 12-50029561

Address: 40 Baptist Grove Road

Insulation: 12-50029561

Fuquay Varina NC 27526

Plumbing: 12-50029561

Mechanical: 12-50029561

MFG Home: NANANANANA

Date: 03-15-2013

Building Official: BSutton

ADDRESS : 40 BAPTIST GROVE RD SUBDIV:  
 CONTRACTOR : PHONE :  
 OWNER : MURPHY LUTIE T PHONE : (910) 890-6424  
 PARCEL : 08-0653- - -0039- - -  
 APPL NUMBER: 12-50029561 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 08/16/2012 08:15 AM JBROCK ----  
 US 401 NORTH TO CHALYBEATE RD & RR  
 CROSSING VEER LEFT ONE MILE TO BAPTITST  
 GROVE RD TURN LEFT 40 BAPTIST GROVE RD  
 NEXT TO CEMERTARY

**STRUCTURE: 000 000 58.3/4X60 4BDR GARAGE & DECK**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/10/12 9/10/12	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002276209 T/S: September 10, 2012 11:40 AM BSUTTON ----- Clean out right rear corner before pouring (washed in) Need premise number to call for tpole power
A814 01	9/14/12 9/17/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002278521 40 baptist grove rd fuquay marina 27526----- T/S: 09/17/2012 11:59 AM TWARD -----
B103 01	9/24/12 9/24/12	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002281830 T/S: September 24, 2012 12:36 PM BSUTTON -----
B105 01	10/22/12 10/22/12	BS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002293231 T/S: October 22, 2012 12:12 PM BSUTTON -----
R125 01	11/30/12 12/06/12	BS AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002309821 SHEATHING INSPECTION ONLY - CUSTOMER PAID T/S: 11/29/2012 08:39 AM JBROCK ----- T/S: December 06, 2012 02:59 PM BSUTTON -----
R425 01	12/04/12 12/04/12	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002311363 OPEN INSPECTION FROM 11/30 CUSTOMER CALLED TODAY FOR ROUGH IN T/S: December 04, 2012 09:42 AM BSUTTON ----- No pressure on gas test. 2. Master tub/shower/whirlpool leaking underneath. either from drain or circulation lines. ok to side/insulate
I129 01	12/17/12 12/17/12	BS AP	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002316693 T/S: 12/14/2012 08:25 AM VBROWN ----- T/S: December 17, 2012 12:23 PM BSUTTON -----
R425 02	12/17/12 12/17/12	BS AP	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002316719 T/S: 12/14/2012 08:25 AM VBROWN ----- T/S: December 17, 2012 12:23 PM BSUTTON -----
H824 01	1/08/13 1/08/13	JM AP	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002327427 T/S: 01/15/2013 08:22 AM SSTEWARD ----- T/S: 01/15/2013 08:22 AM SSTEWARD -----
E209 01	2/25/13 2/25/13	KS AP	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002342731 T/S: 02/22/2013 01:14 PM VBROWN ----- T/S: 02/25/2013 02:42 PM KSLATTUM -----
R429 01	3/15/13 <i>3-15-13</i>	TI <i>APBS</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002351864 T/S: 03/14/2013 08:12 AM VBROWN -----

COMMENTS AND NOTES

ADDRESS : 40 BAPTIST GROVE RD  
CONTRACTOR :  
OWNER : MURPHY LUTIE T  
PARCEL : 08-0653- - -0039- - -  
APPL NUMBER: 12-50029561 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/16/2012 08:15 AM JBROCK ----  
US 401 NORTH TO CHALYBEATE RD & RR  
CROSSING VEER LEFT ONE MILE TO BAPTITST  
GROVE RD TURN LEFT 40 BAPTIST GROVE RD  
NEXT TO CEMERTARY

SUBDIV:  
PHONE :  
PHONE : (910) 890-6424

STRUCTURE: 000 000 58.3/4X60 4BDR GARAGE & DECK

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4000000.00  
SEPTIC - EXISTING? : NEW  
PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/10/12 9/10/12	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002276209 T/S: September 10, 2012 11:40 AM BSUTTON ----- Clean out right rear corner before pouring (washed in) Need premise number to call for tpole power
A814 01	9/14/12 9/17/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002278521 40 baptist grove rd fuquay varina 27526----- T/S: 09/17/2012 11:59 AM TWARD -----
B103 01	9/24/12 9/24/12	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002281830 T/S: September 24, 2012 12:36 PM BSUTTON -----
B105 01	10/22/12 10/22/12	BS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002293231 T/S: October 22, 2012 12:12 PM BSUTTON -----
R125 01	11/30/12	TI	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002309821 SHEATHING INSPECTION ONLY - CUSTOMER PAID T/S: 11/29/2012 08:39 AM JBROCK -----

*11.30.12* *APP*

COMMENTS AND NOTES

-----  
ADDRESS . . : 40 BAPTIST GROVE RD  
CONTRACTOR :  
OWNER . . . : MURPHY LUTIE T  
PARCEL . . . : 08-0653- - -0039- - -  
APPL NUMBER: 12-50029561 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 08/16/2012 08:15 AM JBROCK -----  
US 401 NORTH TO CHALYBEATE RD & RR  
CROSSING VEER LEFT ONE MILE TO BAPTITST  
GROVE RD TURN LEFT 40 BAPTIST GROVE RD  
NEXT TO CEMERTARY  
-----

-----  
**STRUCTURE: 000 000 58.3/4X60 4BDR GARAGE & DECK**  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 4000000.00  
SEPTIC - EXISTING? . . . . : NEW  
PROPOSED USE . . . . . : SFD  
WATER SUPPLY . . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/10/12 9/10/12	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002276209 T/S: September 10, 2012 11:40 AM BSUTTON ----- Clean out right rear corner before pouring (washed in) Need premise number to call for tpole power
A814 01	9/14/12 9/17/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002278521 40 baptist grove rd fuquay varina 27526----- T/S: 09/17/2012 11:59 AM TWARD -----
B103 01	9/24/12 9/24/12	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002281830 T/S: September 24, 2012 12:36 PM BSUTTON -----
B105 01	10/22/12 10/22/12	BS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002293231 T/S: October 22, 2012 12:12 PM BSUTTON -----
R125 01	11/30/12	TI	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002309821 SHEATHING INSPECTION ONLY - CUSTOMER PAID T/S: 11/29/2012 08:39 AM JBROCK -----
R425 01	12/04/12 <i>12-4-12</i>	TI <i>DABS</i>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002311363 OPEN INSPECTION FROM 11/30 CUSTOMER CALLED TODAY FOR ROUGH IN

----- COMMENTS AND NOTES -----

ADDRESS . . : 40 BAPTIST GROVE RD  
 CONTRACTOR :  
 OWNER . . : MURPHY LUTIE T  
 PARCEL . . : 08-0653- - -0039- - -  
 APPL NUMBER: 12-50029561 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 08/16/2012 08:15 AM JBROCK ----  
 US 401 NORTH TO CHALYBEATE RD & RR  
 CROSSING VEER LEFT ONE MILE TO BAPTITST  
 GROVE RD TURN LEFT 40 BAPTIST GROVE RD  
 NEXT TO CEMERTARY

**STRUCTURE: 000 000 58.3/4X60 4BDR GARAGE & DECK**

FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 4000000.00  
 SEPTIC - EXISTING? . . . . : NEW  
 PROPOSED USE . . . . . : SFD  
 WATER SUPPLY . . . . . : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	9/10/12 9/10/12	BS AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002276209 T/S: September 10, 2012 11:40 AM BSUTTON ----- Clean out right rear corner before pouring (washed in) Need premise number to call for tpole power
A814 01	9/14/12 9/17/12	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002278521 40 baptist grove rd fuquay varina 27526----- T/S: 09/17/2012 11:59 AM TWARD -----
B103 01	9/24/12 9/24/12	BS AP	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002281830 T/S: September 24, 2012 12:36 PM BSUTTON -----
B105 01	10/22/12 10/22/12	BS AP	R*OPEN FLOOR TIME: 17:00 VRU #: 002293231 T/S: October 22, 2012 12:12 PM BSUTTON -----
R125 01	11/30/12 12/06/12	BS AP	ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002309821 SHEATHING INSPECTION ONLY - CUSTOMER PAID T/S: 11/29/2012 08:39 AM JBROCK ----- T/S: December 06, 2012 02:59 PM BSUTTON -----
R425 01	12/04/12 12/04/12	BS DA	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002311363 OPEN INSPECTION FROM 11/30 CUSTOMER CALLED TODAY FOR ROUGH IN T/S: December 04, 2012 09:42 AM BSUTTON ----- No pressure on gas test. 2. Master tub/shower/whirlpool leaking underneath. either from drain or circulation lines. ok to side/insulate
I129 01	12/17/12	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002316693 T/S: 12/14/2012 08:25 AM VBROWN -----
R425 02	12/17/12	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002316719 T/S: 12/14/2012 08:25 AM VBROWN -----

COMMENTS AND NOTES