



December 13, 2012

Matthew Lee
880 Sticklands Crossroads Road
Four Oaks, NC 27524
Ph: 919-820-1054

Re.: Foundation
Plan: Caulder Residence
Project No.: 1201-010360

To Whom It May Concern:

As requested, a representative of Tyndall Engineering and Design, PA (TE&D) has reviewed the approved plans for the above referenced project. Specifically, the following items listed were modified:

- 1) Footings under Great Room Beam plan

The following conclusions and recommendations were presented for the above-mentioned items:

- 1) Based on our supplemental plan review and analysis, the W8x67 beam above the Great Room shall be supported by a 30"x30"x10" deep concrete footing on the right side and a 36"x36"x12" deep concrete footing on the left side. The reader is referred to the attached sheet.

We appreciate being able to assist you with this project. If you need further assistance or require additional information please do not hesitate to contact us.

Sincerely,
Tyndall Engineering & Design

Arthur Simmons, EI
1201-010360

Prentice Tyndall, Jr. P.E.

