

October 8, 2012

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

Stancil Builders, Inc.
466 Stancil Road
Angier, NC 27501

ph: 910-893-7547
fax: 910-893-9371

**Re: Status of Improvement Permit Application #12-5-29697 & #12-5-29698
Cokesbury Park III, Lt. 47 and Lt. 48**


To Whom It May Concern,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible *(\$25.00 fee incurred)*
- 2. Use orange flags to mark house corners *(\$25.00 fee incurred)*
- 3. Directions not clear to property *(\$25.00 fee incurred)*
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. **Other – Please have your soil consultant contact us regarding the septic areas for these two lots.**

Your application will be put on hold until the selected items above have been addressed. When completed please call 910-893-7547 to confirm that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,


Oliver Tolksdorf, R.E.H.S.
Environmental Health Soil Scientist
Harnett County Department of Public Health

OT/sgs
Copy: Central Permitting