

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: 9/18/12
 Proposed Facility: 3 septic tank Design Flow (.1949): 360 gpd
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	25 7-10	0-28"	G S	VF2 SS/HP					
		28-32"	G S BK SCL	F2 SS/HP					PS .5
		32"+	PM						
2		0-24"	G S	VF2 SS/HP					
		24-39"	S BK SCL	F2 SS/HP					PS .5
3		0-30"	G S	VF2 SS/HP					
		30-48"	S BK SCL	F2 SS/HP					PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BT Others Present: /
Available Space (.1945)	✓	✓	
System Type(s)	25% R/S		
Site LTAR	.5	.5	

2260E 8/20