

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 436 ROOM      Design Flow (.1949): 280 gpd      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1		0-22"	G S	VFA NS/NP					
		22-41"	SBK <sup>+</sup> SCL <sup>+</sup>	FR SS/NP					PS .5
		44"	~50% PM	F					
2		0-24"	G S	VFA NS/NP					
		24-39"	SBK <sup>+</sup> SCL <sup>+</sup>	FR SS/NP					PS .5
		39"	PM						
3		0-31"	G S	VFA NS/NP					
		31-42"	SBK <sup>+</sup> SCL <sup>+</sup>	FR SS/NP					PS .5
		42"	PM						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>OT</u> Others Present: <u>—</u>
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>AS<sup>2</sup> RG</u>		
Site LTAR	<u>.5</u>	<u>.5</u>	