

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 10/17/12
 Proposed Facility: LABORUM Design Flow (.1949): 420 GPD Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-27	GS	VFA NS/NP					
		27-37	SBX SL	VFA NS/NP					PS .55
		37-48	GS	VFA NS/NP					
2		0-23	GS	VFA NS/NP					
		23-48"	SCL	F2 SS/SP	10x27/1 @ 41"				PS .45
3		0-36	GS	VFA NS/NP					
		36-48	SBX SCL	F2 NS/NP					PS .5

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: OX Others Present: -
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	PUMP 25% PEG		
Site LTAR	5	45	

1x240 @ 36" NO STEPS