

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: ~~10/17/12~~ 10/17/12
 Proposed Facility: 4 Broom Design Flow (.1949): 480 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5%	0-38	GS	VF2 NS/NP					
		38-48	GLS	VF2 NS/NP					S .8
2		0-29	GS	VF2 NS/NP					
		29-48	SB2 SCL	F2 SS/NP					P3 .5
3		0-75"	GS	VF2 NS/NP					
		15-30"	SBK SCL	F2 S/SP	10YR 7/2R 2.5"				P3 .4

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946): Site Classification (.1948): P3 Evaluated By: CJ Others Present: -
Available Space (.1945)			
System Type(s)	4 NP 2.5% RLD		
Site LTAR	.5	.4	

1x24" @ 30-24"