

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: 1

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Seelye Homes LLC

Address: 22 Shepard Dr

Date: _____

Permit Numbers

Building: _____

Electrical: 5

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Building Official: _____

29775

ADDRESS : 122 SHEPARD DR
CONTRACTOR : SAVVY HOMES, LLC
OWNER : ABJ INVESTMENTS LLC
PARCEL : 12-0555- - -0216- -64-
APPL NUMBER: 12-50029775 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/20/2012 09:58 AM JBROCK ----
210 TOWARDS FAYETTEVILLE TAKE LEFT AT
MCNEILL HOBBS RD FOLLOW FOR ABOUT 4.5
MILES TO R AT WIRE RD KENLAN S/D IS
LOCATED APPROX 3.5 MILES ON THE R LOT
60

SUBDIV: KENLAN FARMS PH1SECT2
PHONE : (919) 781-8104
PHONE : (910) 485-5790

STRUCTURE: 000 000 60X65 4BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00
SEPTIC - EXISTING? : NEW
PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|-------------|--|
| B101 01 | 3/22/13 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 002355543 |
| | 3/22/13 | AP | |
| B103 01 | 4/01/13 | VC | R*BLDG FOUND & TEMP SVC POLE VRU #: 002358786 |
| | 4/01/13 | CA | T/S: 04/01/2013 08:46 AM VBROWN ----- DAVE CALLED AND CA INSP |
| A814 01 | 4/03/13 | TW | ADDRESS-CONFIRMATION TIME: 17:00 VRU #: 002360477 |
| | 4/08/13 | AP | 122 shepard dr lot 60 linden 28356 ----- T/S: 04/08/2013 10:36 AM TWARD ----- |
| B103 02 | 4/03/13 | JH | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002360469 |
| | 4/03/13 | AP | T_POLE PASSED ----- |
| P309 01 | 4/08/13 | JH | R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002362580 |
| | 4/08/13 | AP | |
| B111 01 | 4/10/13 | JH | R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002364248 |
| | 4/10/13 | AP | |
| R425 01 | 6/10/13 | JH | FOUR TRADE ROUGH IN VRU #: 002393783 |
| | 6/10/13 | CA | PER DAVE ----- |
| R425 02 | 6/13/13 | JH | FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002396141 |
| | 6/13/13 | DA | 1)Missing 2x10 header over water heater in garage & strap top plate with 24" straps.2)Blocking for point load missing in garage @ house door.3)Blocking for point load in kitchen missing.4)Missing nail guard on plumbing in kitchen pantry.5)Missing 4(3) stud cavities in kitchen opening @ hall.6)Missing 2x8 header under stairs.7)Nail guards on plumbing in master bed not per code.8)Missing header over door in game room.9)3' head of water on drain line test. |
| R425 03 | 6/17/13 | JH | FOUR TRADE ROUGH IN VRU #: 002397339 |
| | 6/17/13 | CA | PER DAVE -- |
| R425 04 | 6/18/13 | JH | FOUR TRADE ROUGH IN VRU #: 002397990 |
| | 6/18/13 | AP | |
| I129 01 | 6/21/13 | JH | R*INSULATION INSPECTION TIME: 17:00 VRU #: 002400562 |
| | 6/21/13 | AP | |
| R125 01 | 7/12/13 | MR | ONE TRADE ROUGH IN TIME: 17:00 VRU #: 002409134 |
| | 7/12/13 | AP | wire for stone inspection T/S: 07/12/2013 03:05 PM MREARIC ----- |

ADDRESS : 122 SHEPARD DR
CONTRACTOR : SAVVY HOMES, LLC
OWNER : ABJ INVESTMENTS LLC
PARCEL : 12-0555- - -0216- -64-
APPL NUMBER: 12-50029775 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1SECT2
PHONE : (919) 781-8104
PHONE : (910) 485-5790

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|--------------------------|-------------------|---|
| E209 01 | 7/18/13 7/18/13 | DT DA | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002411734 T/S: 07/17/2013 03:00 PM VBROWN ----- T/S: 07/18/2013 10:54 AM DETAYLOR ----- Need ladder to access attic Fasten plate for master bath switches |
| E209 02 | 7/31/13 7/31/13 | MR AP | R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002418044 T/S: 07/31/2013 02:50 PM MREARIC ----- |
| H824 01 | 8/05/13 8/05/13 | OT AP | ✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002421683 T/S: 08/06/2013 11:48 AM SSTEWARDT ----- T/S: 08/06/2013 11:48 AM SSTEWARD ----- |
| R429 01 | 8/07/13 <i>8-7-13</i> | TI <i>APTB</i> | FOUR TRADE FINAL TIME: 17:00 VRU #: 002421840 |

----- COMMENTS AND NOTES -----

ADDRESS : 122 SHEPARD DR SUBDIV: KENLAN FARMS PH1SECT2
CONTRACTOR : SAVVY HOMES, LLC PHONE : (919) 781-8104
OWNER : ABJ INVESTMENTS LLC PHONE : (910) 485-5790
PARCEL : 12-0555- - -0216- -64-
APPL NUMBER: 12-50029775 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 09/20/2012 09:58 AM JBROCK ----
210 TOWARDS FAYETTEVILLE TAKE LEFT AT
MCNEILL HOBBS RD FOLLOW FOR ABOUT 4.5
MILES TO R AT WIRE RD KENLAN S/D IS
LOCATED APPROX 3.5 MILES ON THE R LOT
60

STRUCTURE: 000 000 60X65 4BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 4000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

| TYP/SQ | REQUESTED COMPLETED | INSP RESULT | DESCRIPTION RESULTS/COMMENTS |
|---------|---------------------|--------------|--|
| B101 01 | 3/22/13 | JH | R*BLDG FOOTING / TEMP SVC POLE VRU #: 002355543 |
| | 3/22/13 | AP | |
| B103 01 | 4/01/13 | VC | R*BLDG FOUND & TEMP SVC POLE VRU #: 002358786 |
| | 4/01/13 | CA | T/S: 04/01/2013 08:46 AM VBROWN DAVE CALLED AND CA INSP |
| A814 01 | 4/03/13 | TI | ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002360477 |
| B103 02 | 4/03/13 | TI | R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002360469 |
| | <u>4-3-13</u> | <u>AP JH</u> | <i>T-pole passed</i> COMMENTS AND NOTES |