

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: ___ Occupancy:

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: Savvy Homes LLC

Building: _____

Electrical: _____

Address: 89 Shepard Dr

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

Date: 8-7-13

Building Official: [Signature]

ADDRESS : 88 SHEPARD DR SUBDIV: KENLAN FARMS PH1SECT2
 CONTRACTOR : SAVVY HOMES, LLC PHONE : (919) 781-8104
 OWNER : ABJ INVESTMENTS LLC PHONE : (910) 485-5790
 PARCEL : 12-0555- - -0216- -66-
 APPL NUMBER: 12-50029777 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/20/2012 09:58 AM JBROCK ----
 210 TOWARDS FAYETTEVILLE TAKE LEFT AT
 MCNEILL HOBBS RD FOLLOW FOR ABOUT 4.5
 MILES TO R AT WIRE RD KENLAN S/D IS
 LOCATED APPROX 3.5 MILES ON THE R LOT
 62

STRUCTURE: 000 000 60X65 4BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002356889
	3/26/13	AP	T/S: 03/26/2013 12:31 PM DETAYLOR -----
B103 01	4/01/13	VC	R*BLDG FOUND & TEMP SVC POLE VRU #: 002358844
	4/01/13	CA	T/S: 04/01/2013 08:47 AM VBROWN ----- DAVE CALLED AND CA INSP
A814 01	4/03/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002360519
	4/08/13	AP	88 shepard dr lot 62 linden 28356 ----- T/S: 04/08/2013 10:37 AM TWARD -----
B103 02	4/03/13	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002360501
	4/03/13	AP	T_POLE PASSED -----
P309 01	4/08/13	JH	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002362606
	4/08/13	AP	-----
B111 01	4/10/13	JH	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002364263
	4/10/13	AP	-----
R425 01	6/10/13	JH	FOUR TRADE ROUGH IN VRU #: 002393791
	6/10/13	DA	1)Nail guards per code on all plumbing.2)Missing header over bed4 door.3)Need 3' head of water on drain line test.
R425 02	6/13/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002396158
	6/13/13	AP	-----
I129 01	6/18/13	JH	R*INSULATION INSPECTION VRU #: 002398006
	6/18/13	AP	-----
E209 01	7/18/13	DT	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002411759
	7/18/13	AP	T/S: 07/17/2013 03:02 PM VBROWN ----- T/S: 07/18/2013 10:54 AM DETAYLOR -----
H824 01	8/05/13	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002421675
	8/05/13	AP	T/S: 08/06/2013 11:47 AM SSTEWARD ----- T/S: 08/06/2013 11:47 AM SSTEWARD -----
R429 01	8/07/13	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002421857

8-7-13 APJH

COMMENTS AND NOTES

ADDRESS : 88 SHEPARD DR SUBDIV: KENLAN FARMS PH1SECT2
 CONTRACTOR : SAVVY HOMES, LLC PHONE : (919) 781-8104
 OWNER : ABJ INVESTMENTS LLC PHONE : (910) 485-5790
 PARCEL : 12-0555- - -0216- -66-
 APPL NUMBER: 12-50029777 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 09/20/2012 09:58 AM JBROCK ----
 210 TOWARDS FAYETTEVILLE TAKE LEFT AT
 MCNEILL HOBBS RD FOLLOW FOR ABOUT 4.5
 MILES TO R AT WIRE RD KENLAN S/D IS
 LOCATED APPROX 3.5 MILES ON THE R LOT
 62

STRUCTURE: 000 000 60X65 4BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 4000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/26/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002356889
	3/26/13	AP	T/S: 03/26/2013 12:31 PM DETAYLOR -----
B103 01	4/01/13	VC	R*BLDG FOUND & TEMP SVC POLE VRU #: 002358844
	4/01/13	CA	T/S: 04/01/2013 08:47 AM VBROWN ----- DAVE CALLED AND CA INSP
A814 01	4/03/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002360519
B103 02	4/03/13 <u>4-3-13</u>	TI <u>AA JH</u>	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002360501 <i>Reserve T-pole passed</i>

COMMENTS AND NOTES