

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 10/19/02
 Proposed Facility: 2, *BEDROOMS* Design Flow (.1949): 480 *gpd* Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	R	0-48	G S	VFR NS/NP					S .8
2	SS 5-7	0-48	G S	VFR NS/NP					S .8
3	FS 2-5	0-40"	G S	VFR NS/NP					
		40-48	G SL	VFR NS/NP					S .6
					↑ OUT OF FIELD AREA				

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): S Evaluated By: CT Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	PUMP 25% RED		
Site LTAR	-8	-8	

1x180' @ 30'±24"