

ADDRESS : 52 SHEPARD DR SUBDIV: KENLAN FARMS PH1SECT2  
CONTRACTOR : SAVVY HOMES, LLC PHONE : (919) 781-8104  
OWNER : ABJ INVESTMENTS LLC PHONE : (910) 485-5790  
PARCEL : 12-0555- - -0216- -68-  
APPL NUMBER: 12-50029779 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 09/20/2012 09:58 AM JBROCK ----  
210 TOWARDS FAYETTEVILLE TAKE LEFT AT  
MCNEILL HOBBS RD FOLLOW FOR ABOUT 4.5  
MILES TO R AT WIRE RD KENLAN S/D IS  
LOCATED APPROX 3.5 MILES ON THE R LOT  
64

STRUCTURE: 000 000 60X65 4BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/04/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002346450
	3/04/13	CA	PER DAVE
B101 02	3/05/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002346971
	3/05/13	AP	
B103 01	3/12/13	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002350494
	3/12/13	AP	T_POLE PASSED
A814 01	3/20/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002353795
	3/22/13	AP	52 SHEPARD DR LOT 64 LINDEN 28356 T/S: 03/22/2013 01:09 PM TWARD
P309 01	3/20/13	DT	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002353803
	3/20/13	AP	T/S: 03/20/2013 10:15 AM DETAYLOR
B111 01	3/21/13	JH	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002354983
	3/21/13	CA	PER DAVE
B111 02	3/22/13	JH	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002355576
	3/22/13	AP	
R425 01	4/12/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002365757
	4/12/13	CA	PER DAVE
R425 02	4/17/13	JH	FOUR TRADE ROUGH IN VRU #: 002367738
	4/17/13	DA	1)Missing stud @ spare bath sink over 16".2)Missing nail guard @ bottom plate on spare bath sink drain.3)Nail osb @ bottom plate in bonus romm to right of window & under window.
R429 01	4/22/13	DJ	FOUR TRADE FINAL VRU #: 002370443
	4/19/13	CA	T/S: 04/19/2013 02:44 PM DJOHNSON CANCELLED FINAL INSPECTION. CANNOT HAVE FINAL INSPECTION WITHOUT FINAL ON SEPTIC AND INSULATION INSPECTION
R425 03	4/23/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002370807
	4/23/13	AP	
I129 01	4/25/13	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002372472
	4/25/13	CA	PER DAVE
I129 02	4/26/13	DT	R*INSULATION INSPECTION VRU #: 002373314
	4/26/13	CA	T/S: 04/26/2013 09:20 AM DETAYLOR
I129 03	4/30/13	TI	R*INSULATION INSPECTION VRU #: 002374544

4-30-13 *ACTB*