

ADDRESS : 52 SHEPARD DR  
CONTRACTOR : SAVVY HOMES, LLC  
OWNER : ABJ INVESTMENTS LLC  
PARCEL : 12-0555- - -0216- -68-  
APPL NUMBER: 12-50029779 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 09/20/2012 09:58 AM JBROCK ----  
210 TOWARDS FAYETTEVILLE TAKE LEFT AT  
MCNEILL HOBBS RD FOLLOW FOR ABOUT 4.5  
MILES TO R AT WIRE RD KENLAN S/D IS  
LOCATED APPROX 3.5 MILES ON THE R LOT  
64

SUBDIV: KENLAN FARMS PH1SECT2  
PHONE : (919) 781-8104  
PHONE : (910) 485-5790

STRUCTURE: 000 000 60X65 4BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 4000000.00  
SEPTIC - EXISTING? : NEW  
PROPOSED USE : SFD  
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS	
B101 01	3/04/13	JH	R*BLDG FOOTING / TEMP SVC POLE	VRU #: 002346450
	3/04/13	CA	PER DAVE	
B101 02	3/05/13	TI	R*BLDG FOOTING / TEMP SVC POLE	VRU #: 002346971

*3-5-13 AJH*

COMMENTS AND NOTES



**ATC Associates of North Carolina, PC**

2725 E. Millbrook Rd Suite 121 Raleigh, NC 27604  
Phone: 919-871-0999 Fax: 919-871-0335  
[www.atcassociates.com](http://www.atcassociates.com)

March 4, 2013

Mr. George Aiken  
Savvy Homes  
6030 Creedmoor Road, Suite 101  
Raleigh, NC 27612  
Ph: 919-781-8104 Fax: 919-781-8105

Re: Footing Evaluation for Lot 64 Kenlan Farms in Harnett County, North Carolina. ATC  
Project Number: 45.34028.00017


Dear Mr. Aiken,

ATC re-visited the above referenced site to observe and evaluate foundation soils for Lot 64. At the time of our visit, building pad construction and footing excavation were complete. It appears footings will bear on natural soils.

Using a ½ inch diameter steel probe rod and DCP, ATC tested soils at bottom of footing elevation. Test results indicate soils should be satisfactory to support a foundation designed for a net allowable bearing capacity of 2,000 psf. ATC recommends 2 #4 rebar for continuous footings.

Respectfully,

ATC Associates of North Carolina, PC



Herbert L. Hales, II, P.E.  
Project Engineer