

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 *Residential*      Design Flow (.1949): 360 *gpd*      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:                       Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L3 5-7%	0-16	G S	VF2 NS/NP					
		16-38	G LS	VF2 NS/NP					S .8
		38" <sup>+</sup>	Pm						
2		0-24"	G S	VF2 NS/NP					
		24-48"	G LS	VF2 NS/NP					S .8
3		0-24"	G S	VF2 NS/NP					
		24-40"	G SL	VF2 SS/NP					S .6
		40" <sup>+</sup>	G S	VF2 NS/NP					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: GT Others Present: -
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	PUMP 25% (RCS)		
Site LTAR	.6	.6	

