

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 10/19/12
 Proposed Facility: 4360 20m Design Flow (.1949): 480 gal
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2	0-6 0-6"	G SL	VFR NS/NP					US
		6"	MC						
2		0-10"	G S	VFR NS/NP	BLACK				
		10"	SBK CL	FR S/P	10" X 2 5/8" @ 13"				US
3		0-36"	G S	VFR NS/NP					S, R
		36"	COARSE S PM	FR VFR NS/NP					
4		0-36"	FINE G S	VFR NS/NP					
		36-41"	COARSE G S	VFR NS/NP					S, R

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): S Evaluated By: OT Others Present: 1
Available Space (.1945)			
System Type(s)	PUMP 2 1/2" @ 2 1/2"		
Site LTAR	S	R	

1x180' PUMP 18-36" FINAL LAYOUT WHEN CHARGED