

ADDRESS : 147 SHEPARD DR  
 CONTRACTOR : SAVVY HOMES, LLC  
 OWNER : KENLAN DEVELOPMENT CO  
 PARCEL : 12-0555- - -0216- -49-  
 APPL NUMBER: 12-50029828 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 09/28/2012 10:25 AM JBROCK ----  
 210 TOWARD FAY TAKE L AT MCNEILL HOBBS  
 RD FOLLOW FOR ABOUT 4.5 MILES TO TURN R  
 AT WIRE RD KENLAN FARMS S/D IS LOCATED  
 APPROX 3.5 MILES ON THE R LOT 45

SUBDIV: KENLAN FARMS PH1SECT2  
 PHONE : (919) 781-8104  
 PHONE :

**STRUCTURE: 000 000 56X42.3 4BDR SLAB W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 4000000.00  
 SEPTIC - EXISTING? : NEW TANK  
 PROPOSED USE : SFD  
 WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/03/12	JH	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002310860
	12/03/12	AP	
B103 01	12/07/12	JH	R*BLDG FOUND & TEMP SVC POLE VRU #: 002313260
	12/07/12	AP	T-POLE PASSED
P309 01	12/13/12	JH	R*PLUMB UNDER SLAB VRU #: 002315810
	12/13/12	AP	
P307 01	12/14/12	JH	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002316156
	12/14/12	AP	
A814 01	12/17/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002317162
	12/21/12	AP	147 SHEPARD DR LOT 45 LINDEN 28356 T/S: 12/21/2012 12:41 PM TWARD
B111 01	12/17/12	DT	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002317154
	12/17/12	AP	T/S: 12/17/2012 01:55 PM DETAYLOR TPole passed
R425 01	1/29/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002332179
	1/29/13	CA	PER JOSH
R425 02	1/30/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002332740
	1/30/13	CA	PER JOSH
R425 03	1/31/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002333359
	1/31/13	DA	1)Need 3 studs under each end of lvl in garage per plans.2)Water line @ water heater leaking @ valve.3)Missing stud to left of right window in living room.4)Missing 4 studs on end wall to right of fire place.5)Missing 4 studs under each end of girder truss over foyer per plans.6)Missing 4 studs under girder truss in master closet on end wall per plans.7)Missing air barriers in chase @ bed 2 closet & back wall of laundry room.
R425 04	2/01/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002334019
	2/01/13	AP	
I129 01	2/11/13	TI	R*INSULATION INSPECTION VRU #: 002337335

*2-11-13 ACJA*

COMMENTS AND NOTES

PREPARED 12/14/12, 16:19:55  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 1  
DATE 12/17/12

ADDRESS : 147 SHEPARD DR  
CONTRACTOR : SAVVY HOMES, LLC  
OWNER : KENLAN DEVELOPMENT CO  
PARCEL : 12-0555- - -0216- -49-  
APPL NUMBER: 12-50029828 CP NEW RESIDENTIAL (SFD)

SUBDIV: KENLAN FARMS PH1SECT2  
PHONE : (919) 781-8104  
PHONE :

DIRECTIONS : T/S: 09/28/2012 10:25 AM JBROCK ----  
210 TOWARD FAY TAKE L AT MCNEILL HOBBS  
RD FOLLOW FOR ABOUT 4.5 MILES TO TURN R  
AT WIRE RD KENLAN FARMS S/D IS LOCATED  
APPROX 3.5 MILES ON THE R LOT 45

**STRUCTURE: 000 000 56X42.3 4BDR SLAB W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X

# BEDROOMS : 4000000.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	12/03/12 12/03/12	JH AP	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002310860
B103 01	12/07/12 12/07/12	JH AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002313260 T-POLE PASSED
P309 01	12/13/12 12/13/12	JH AP	R*PLUMB UNDER SLAB VRU #: 002315810
P307 01	12/14/12 12/14/12	JH AP	R*PLUMB WATER CONNECTION TIME: 17:00 VRU #: 002316156
A814 01	12/17/12	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002317162
B111 01	12/17/12 <u>12/17/12</u>	TI <u>AP DF</u>	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002317154

COMMENTS AND NOTES