

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Genesis Living, Inc

Address: 21 Curr Well Dr.
Benson, NC 27504

Date: 12/4/12

Building Official: _____

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: 1250029845

MFG Home: _____

[Signature]

ADDRESS : 21 CURR WELL DR SUBDIV:
 CONTRACTOR : GENESIS LIVING, INC PHONE : (919) 337-2172
 OWNER : CURR-WELL DEVELOPMENT PHONE :
 PARCEL : 07-1602- - -0055- -01-
 APPL NUMBER: 12-50029845 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 10/01/2012 02:05 PM JBROCK ----
 HWY 27 FORM COATS TO BENSON LEFT ON
 BAILEYS XRDS RD S/D APPROX 2 MILES ON
 RIGHT LOT 1
 PREMISE # 00957100

STRUCTURE: 000 000 36X67.2 3BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/15/12	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002291151
	10/15/12	AP	T/S: 10/15/2012 01:56 PM KSLATTUM -----
A814 01	10/18/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002292217
	10/24/12	AP	21 curr well dr lot 1 benson 27504----- T/S: 10/24/2012 03:50 PM TWARD -----
B103 01	10/18/12	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002292209
	10/18/12	AP	T/S: 10/18/2012 02:11 PM KSLATTUM -----
B105 01	10/19/12	KS	R*OPEN FLOOR TIME: 17:00 VRU #: 002292977
	10/19/12	AP	T/S: 10/18/2012 12:50 PM VBROWN ----- T/S: 10/19/2012 11:39 AM KSLATTUM -----
E207 01	10/19/12	KS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002292985
	10/19/12	CA	T/S: 10/18/2012 12:50 PM VBROWN ----- T/S: 10/19/2012 11:39 AM KSLATTUM ----- previously called in
R425 01	11/01/12	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002298123
	11/01/12	AP	T/S: 11/01/2012 02:39 PM KSLATTUM -----
I129 01	11/05/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002299246
	11/05/12	DA	T/S: 11/05/2012 09:33 AM KSLATTUM ----- Wrong insulation r values. Harnett County is zone 4
I129 02	11/07/12	FS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002299980
	11/07/12	AP	T/S: 11/07/2012 03:18 PM FSPIVEY -----
H824 01	11/14/12	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002304020
	11/14/12	AP	T/S: 11/15/2012 11:01 AM SSTEWARD ----- T/S: 11/15/2012 11:01 AM SSTEWARD -----
R429 01	12/04/12	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002311355

12/4/12 APDR

COMMENTS AND NOTES

ADDRESS . : 21 CURR WELL DR SUBDIV:
CONTRACTOR : GENESIS LIVING, INC PHONE : (919) 337-2172
OWNER . . : CURR-WELL DEVELOPMENT PHONE :
PARCEL . . : 07-1602- - -0055- -01-
APPL NUMBER: 12-50029845 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 10/01/2012 02:05 PM JBROCK ----
HWY 27 FORM COATS TO BENSON LEFT ON
BAILEYS XRDS RD S/D APPROX 2 MILES ON
RIGHT LOT 1
PREMISE # 00957100

STRUCTURE: 000 000 36X67.2 3BDR CRAWL W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	10/15/12	KS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002291151
	10/15/12	AP	T/S: 10/15/2012 01:56 PM KSLATTUM -----
A814 01	10/18/12	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002292217
	10/24/12	AP	21 curr well dr lot 1 benson 27504----- T/S: 10/24/2012 03:50 PM TWARD -----
B103 01	10/18/12	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002292209
	10/18/12	AP	T/S: 10/18/2012 02:11 PM KSLATTUM -----
B105 01	10/19/12	KS	R*OPEN FLOOR TIME: 17:00 VRU #: 002292977
	10/19/12	AP	T/S: 10/18/2012 12:50 PM VBROWN ----- T/S: 10/19/2012 11:39 AM KSLATTUM -----
E207 01	10/19/12	KS	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002292985
	10/19/12	CA	T/S: 10/18/2012 12:50 PM VBROWN ----- T/S: 10/19/2012 11:39 AM KSLATTUM ----- previously called in
R425 01	11/01/12	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002298123
	11/01/12	AP	T/S: 11/01/2012 02:39 PM KSLATTUM -----
I129 01	11/05/12	KS	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002299246
	11/05/12	DA	T/S: 11/05/2012 09:33 AM KSLATTUM -----
I129 02	11/07/12	TI	Wrong insulation r values. Harnett County is zone 4 R*INSULATION INSPECTION TIME: 17:00 VRU #: 002299980

Handwritten: 11-7-12 AP FS

COMMENTS AND NOTES
