

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 38025 Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 7-10	0-32	G S	VFN NS/NP					
		32-48	G SL	VFN NS/NP					S .6
		0-18	G S	VFN NS/NP					
		18-38	SBK SL ⁺	FR SS/NP					PS .5
		0-20	G S	VFN NS/NP					
		20-36	SBK SL ⁺	FR SS/NP					PS .5
		0-24	G S	VFN NS/NP					
		24-38	SBK SL ⁺	FR SS/NP					PS .5
		0-27	G S	VFN NS/NP					
		27-36	SBK SL ⁺	FR SS/NP					PS .5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	25" x 18" x 24"		
Site LTAR	S	.5	

1 x 18" @ 18" x 24"