

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: _____
 Proposed Facility: 4860 Design Flow (.1949): 480 Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (in.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	L5 6-20	0-4"	G 3	VFA NSHP					S.8
2		0-4"	G 3	VFA NSHP					S.8

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>S</u> Evaluated By: <u>OT</u> Others Present: _____
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>25" u/s</u>		
Site LTAR	<u>8</u>	<u>8</u>	

4 ~~3~~ 50" @ 24-30"