

12500
HTE# 30166

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Greg Bayley PHONE # 919-609-0300
ADDRESS 86 Derby Ln Lillington N.C. 27546
NAME OF MOBILE HOME PARK OR S/D _____
NAME OF OWNER (IF DIFFERENT) Ibrahim Oudeh
ADDRESS OF OWNER (IF DIFFERENT) 801 Tilghman Dr.
PROPERTY LOCATION: STATE ROAD NAME AND # Cokesbury Rd.

PURPOSE OF INSPECTION:

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

A. H. Byrd R.E.H.S.
Signature of Environmental Health Specialist

12/13/12
Date