

December 12, 2012

Wicker Construction Corp
5190 Buckhorn Road
Sanford, Nc27330

ph: 910-893-7547
fax: 910-893-9371

Re: Status of Improvement Permit Application # 12-5-30214

Dear Mr. Wicker,


An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible (*\$25.00 fee incurred*)
- 2. Use orange flags to mark house corners (*\$25.00 fee incurred*)
- 3. Directions not clear to property (*\$25.00 fee incurred*)
- 4. Property needs only brush or vegetation removed
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,

 RGS

Oliver Tolksdorf, R.E.H.S.
Environmental Health OSWW Soil Scientist
Harnett County Department of Public Health

OT/sgs
Copy: Central Permitting