

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BATHROOM Design Flow (.1949): 36 GPD
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	SS 7-16%	0-40	GS	VFI NS/SP					
		40-48	SBK SLL	FI SS/SP					PS .45
2		0-28	GS	VFI NS/SP					
		28-34	SBK SLL	FI SS/SP					PS .45
		34"	Pm						
3		0-24	GS	VFI NS/SP					
		24-33	SBK SLL	FI SS/SP					PS .45
		33"	Pm						

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: [Signature]
Available Space (.1945)	✓	✓	
System Type(s)	25" x 18"	25"	
Site LTAR	.45	.45	

1 x 20" x 18"

