

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 11802m Design Flow (.1949): 480 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<u>LS</u> <u>45</u>	<u>0-8"</u>	<u>GS</u>	<u>VFNS/VP</u>					
		<u>8-27"</u>	<u>SBK SBL</u>	<u>F2 SS/S</u>	<u>10Y2/2 27"</u>				<u>P5</u> <u>.45</u>
2		<u>0-6"</u>	<u>GS</u>	<u>VFNS/VP</u>					
		<u>6-32"</u>	<u>SBK SCL</u>	<u>F2 SS/S</u>	<u>10Y2/2 32"</u>				<u>P5</u> <u>.45</u>
3		<u>0-8"</u>	<u>GS</u>	<u>VFNS/VP</u>					
		<u>24-27"</u>	<u>SBL SCL</u>	<u>F2 SS/S</u>					<u>P5</u> <u>.55</u>
4		<u>0-12"</u>	<u>GS</u>	<u>VFNS/VP</u>					
		<u>12-26"</u>	<u>SBK SCL</u>	<u>F2 SS/S</u>	<u>10Y2/2 26"</u>				<u>P5</u> <u>.45</u>

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>P4</u> Evaluated By: <u>[Signature]</u> Others Present: <u>[Signature]</u>
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>PUMP</u>	<u>35' x 26'</u>	
Site LTAR	<u>LS</u>	<u>LS</u>	