

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: _____ Applicant: _____
 Address: _____ Date Evaluated: _____
 Proposed Facility: 3 bedrooms Design Flow (.1949): 360 gpd Property Size: _____
 Location of Site: _____ Property Recorded: _____
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L5 7-10	0-32	GS	VFr ns/NP					
		32-44	SBK SCL	F2 ss/NP					PS .5
		0-24	GS	VFr ns/NP					
		24-36	SBK SCL	F2 ss/NP					PS .5
		36" PM	PM						
		0-27	GS	VFr ns/NP					
		27-42	SBK SCL	F2 ss/NP					PS .5
		42" PM	PM						


Description	Initial System	Repair System	Other Factors (.1946): _____ Site Classification (.1948): <u>PS</u> Evaluated By: <u>CS</u> Others Present: _____
Available Space (.1945)			
System Type(s)	<u>2.5% (60)</u>		
Site LTAR	<u>.5</u>	<u>.5</u>	

MAP NO. 2012-551

"BLACK DIAMOND CT."
50' R/W


CURVE	RADIUS	LENGTH	CHORD	CH. BEARING
C-1	50.00'	40.06'	39.00'	N 36°49'44"E

SITE PLAN APPROVAL
 DISTRICT RA-20R USE SFD
 # BEDROOMS 3
1-2-13
djamon
 ZONING ADMINISTRATOR



MAP REFERENCE: MAP NO. 2012-551

MINIMUM BUILDING SET BACKS
 FRONT YARD — 30'
 REAR YARD — 20'
 SIDE YARD — 10'
 CORNER LOT SIDE YARD — 20'
 MAXIMUM HEIGHT — 30'



TOWNSHIP		BARBECUE		COUNTY		HARNETT		25' 0 50'		SURVEYED BY:		FIELD BOOK	
STATE:		NORTH CAROLINA		DATE:		DECEMBER 12, 2012		SCALE: 1" = 50'		DRAWN BY: RVB		DRAWING NO.	
ZONE		RA-20R		WATERSHED DISTRICT		TAX PARCEL ID#:		CHECKED & CLOSURE BY:		12425		JOB NO. 12425	
SURVEY FOR: PROPOSED PLOT PLAN - LOT - 75 "TROTTER'S RIDGE S/D", PHASE - 2-A										BENNETT SURVEYS 1662 CLARK RD., LILLINGTON, N.C. 27546 (810) 893-5252			