

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3805 Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 5-7	0-16"	G SL	VF2 NS/HP					
		16-36"	SBK SCL	F2 SS/SP					PS .4
		36" ^{1/2}	SBK C	F1 S/P	10YR7/2 @ 36"				
2		0-15"	G SL	VF2 NS/HP					
		15-26"	SBK SCL	F2 SS/SP					
		36" ^{1/2}	SBK C	F2 S/P	10YR7/2 @ 36"				PS .4
3		0-12"	G SL	VF2 NS/HP					
		12" ^{1/2}	SBK SCL	F2 S/SP	10YR7/2 @ 20"				US
4		0-8"	G SL	VF2 NS/HP					
		8" ^{1/2}	SBK C	F2 S/P	10YR7/2 @ 22"				US

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>RS</u> Evaluated By: <u>AK</u> Others Present: <u>1</u>
Available Space (.1945)	<u>J</u>	<u>J</u>	
System Type(s)	<u>2.5" x 4" R50</u>	<u>4</u>	
Site LTAR	<u>.2</u>	<u>4</u>	