

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: _____ **Occupancy:** X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: Residential

Name: Brian K Walker

Address: 340 Willowcroft Ct
Dunn, NC 28334

Date: 10-4-13

Building Official: _____

Permit Numbers

Building: _____

Electrical: _____

Insulation: _____

Plumbing: _____

Mechanical: _____

MFG Home: _____

13-50030361

[Signature]

ADDRESS : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER : WALKER BRIAN K & PHONE : (910) 514-2370
PARCEL : 02-1518- - -0099- -07-
APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/04/2013 02:22 PM JBROCK ----
340 WILLOWCROFT
LEIGH LAUREL S/D LOT 4 ON
PREMISE # 26828234
LAND NOTES : LXMN 6/18/04 LEIGH LAUREL LOT#4
LXMN 6/21/04 SPLIT FROM THE 03 PARCEL

STRUCTURE: 000 000 98.9X62.3 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/13	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002332898
	1/31/13	AP	T/S: January 31, 2013 01:03 PM BSUTTON -----
A814 01	2/15/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002339018
	2/19/13	AP	T/S: 02/14/2013 09:11 AM DJOHNSON ----- 340 WILLOWCROFT CT LOT 4 DUNN 28334----- T/S: 02/19/2013 01:10 PM TWARD -----
B103 01	2/18/13	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002339000
	2/18/13	AP	T/S: 02/14/2013 09:07 AM DJOHNSON ----- PLEASE CALL ROBBIE POPE AT 919-868-2912 WHEN GOING TO JOBSITE. T/S: 02/15/2013 09:22 AM VBROWN ----- T/S: 02/18/2013 02:36 PM KSLATTUM -----
B105 01	2/21/13	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002341600
	2/21/13	AP	T/S: 02/20/2013 01:54 PM VBROWN ----- T/S: 02/20/2013 01:54 PM VBROWN ----- KEN CALL ROBBIE POPE BEFORE YOU GO OUT LATER IN THE AM 919 868 2912 T/S: February 21, 2013 02:22 PM BSUTTON -----
R425 01	4/18/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002368595
	4/18/13	CA	T/S: 04/17/2013 11:57 AM VBROWN ----- T/S: 04/17/2013 11:58 AM VBROWN ----- CONTRACTOR WANTS YOU TO CALL HIM. ROBBY 919 868 2912. PER ROBBY
R425 02	4/22/13	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002370310
	4/22/13	DA	call cell number when going to inspection 919-868-2912 T/S: 04/22/2013 01:08 PM DETAYLOR ----- 1. Missing joist hangers in dining room/by back porch door/and for triple joist. 2. Completely nail all hangers 3. Missing air barriers throughout house 4. Fire block around hood vent 5. Fire block chase to left of fireplace where line set passes 6. Need receptacle accessible from grade on rear of house 7. Fire caulk plumbing for upstairs bath 8. Fasten exhaust duct to fan in upstairs bath 9. Front door must be inspected after installation 10. Support (circled on plans)missing under wall at upstairs

ADDRESS : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
 CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
 OWNER : WALKER BRIAN K & PHONE : (910) 514-2370
 PARCEL : 02-1518- - -0099- -07-
 APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	4/26/13	KS	porch R*INSULATION INSPECTION TIME: 17:00 VRU #: 002373462
	4/26/13	AP	T/S: 04/25/2013 01:15 PM VBROWN T/S: 04/26/2013 01:14 PM KSLATTUM
R425 03	4/26/13	KS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002373488
	4/26/13	AP	T/S: 04/25/2013 01:15 PM VBROWN T/S: 04/26/2013 01:14 PM KSLATTUM
E209 01	8/30/13	KS	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002433555
	8/30/13	AP	T/S: 08/29/2013 12:08 PM VBROWN T/S: 08/30/2013 03:43 PM KSLATTUM
H824 01	9/12/13	JM	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002439529
	9/12/13	AP	T/S: 09/13/2013 11:26 AM SSTEWARD T/S: 09/13/2013 11:27 AM SSTEWARD
R429 01	10/02/13	KS	FOUR TRADE FINAL TIME: 17:00 VRU #: 002447746
	10/03/13	DA	T/S: 10/01/2013 12:52 PM DJOHNSON ROBBIE POPE WOULD LIKE PM INSPECTION AND CAN YOU CALL HIM AT 919-868-2912 BEFORE GOING OUT. T/S: 10/03/2013 02:06 PM KSLATTUM 1. Need energy certificate. 2. Washing machine box shall be 34 inches. 3. Label dryer duct length. 4. Insulation needs re-installation. 5. Seal around attic door. 6. Vent has impeoper drainage in attic. 7. Need shut off accessible for gas logs.
R429 02	10/04/13	TL	FOUR TRADE FINAL TIME: 17:00 VRU #: 002448991
	10/14/13	AP DT	T/S: 10/03/2013 01:38 PM DJOHNSON

----- COMMENTS AND NOTES -----

ADDRESS . . : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
 CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
 OWNER . . . : WALKER BRIAN K & PHONE : (910) 514-2370
 PARCEL . . . : 02-1518- - -0099- -07-
 APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/04/2013 02:22 PM JBROCK ----
 340 WILLOWCROFT
 LEIGH LAUREL S/D LOT 4 ON
 PREMISE # 26828234

LAND NOTES : LXMN 6/18/04 LEIGH LAUREL LOT#4
 LXMN 6/21/04 SPLIT FROM THE 03 PARCEL

STRUCTURE: 000 000 98.9X62.3 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/13 <u>1-31-13</u>	TI <u>AB</u>	R*BLDG FOOTING / TEMP.SVC POLE TIME: 17:00 VRU #: 002332898

----- COMMENTS AND NOTES -----

ADDRESS : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
OWNER : WALKER BRIAN K & PHONE : (910) 514-2370
PARCEL : 02-1518- - -0099- -07-
APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 01/04/2013 02:22 PM JBROCK ----
340 WILLOWCROFT
LEIGH LAUREL S/D LOT 4 ON
PREMISE # 26828234
LAND NOTES : LXMN 6/18/04 LEIGH LAUREL LOT#4
LXMN 6/21/04 SPLIT FROM THE 03 PARCEL

STRUCTURE: 000 000 98.9X62.3 3BDR CRAWL W/ GARAGE & DECK
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 3000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/13	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002332898
	1/31/13	AP	T/S: January 31, 2013 01:03 PM BSUTTON -----
A814 01	2/15/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002339018
			T/S: 02/14/2013 09:11 AM DJOHNSON -----
B103 01	2/18/13	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002339000
	<u>2-18-13</u>	<u>AP</u>	T/S: 02/14/2013 09:07 AM DJOHNSON -----
			PLEASE CALL ROBBIE POPE AT 919-868-2912 WHEN GOING TO JOBSITE.
			T/S: 02/15/2013 09:22 AM VBROWN -----

----- COMMENTS AND NOTES -----

ADDRESS : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
 CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
 OWNER : WALKER BRIAN K & PHONE : (910) 514-2370
 PARCEL : 02-1518- - -0099- -07-
 APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/04/2013 02:22 PM JBROCK ----
 340 WILLOWCROFT
 LEIGH LAUREL S/D LOT 4 ON
 PREMISE # 26828234

LAND NOTES : LXMN 6/18/04 LEIGH LAUREL LOT#4
 LXMN 6/21/04 SPLIT FROM THE 03 PARCEL

STRUCTURE: 000 000 98.9X62.3 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/13	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002332898
	1/31/13	AP	T/S: January 31, 2013 01:03 PM BSUTTON -----
A814 01	2/15/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002339018
	2/19/13	AP	T/S: 02/14/2013 09:11 AM DJOHNSON ----- 340 WILLOWCROFT CT LOT 4 DUNN 28334----- T/S: 02/19/2013 01:10 PM TWARD -----
B103 01	2/18/13	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002339000
	2/18/13	AP	T/S: 02/14/2013 09:07 AM DJOHNSON ----- PLEASE CALL ROBBIE POPE AT 919-868-2912 WHEN GOING TO JOBSITE. T/S: 02/15/2013 09:22 AM VBROWN ----- T/S: 02/18/2013 02:36 PM KSLATTUM -----
B105 01	2/21/13	TI	R*OPEN FLOOR TIME: 17:00 VRU #: 002341600
			T/S: 02/20/2013 01:54 PM VBROWN ----- T/S: 02/20/2013 01:54 PM VBROWN ----- KEN CALL ROBBIE POPE BEFORE YOU GO OUT LATER IN THE AM 919 868 2912

2-21-13 APBS

----- COMMENTS AND NOTES -----

ADDRESS : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
 CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
 OWNER : WALKER BRIAN K & PHONE : (910) 514-2370
 PARCEL : 02-1518- - -0099- -07-
 APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/04/2013 02:22 PM JBROCK ----
 340 WILLOWCROFT
 LEIGH LAUREL S/D LOT 4 ON
 PREMISE # 26828234
 LAND NOTES : LXMN 6/18/04 LEIGH LAUREL LOT#4
 LXMN 6/21/04 SPLIT FROM THE 03 PARCEL

STRUCTURE: 000 000 98.9X62.3 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/13	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002332898
	1/31/13	AP	T/S: January 31, 2013 01:03 PM BSUTTON -----
A814 01	2/15/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002339018
	2/19/13	AP	T/S: 02/14/2013 09:11 AM DJOHNSON ----- 340 WILLOWCROFT CT LOT 4 DUNN 28334----- T/S: 02/19/2013 01:10 PM TWARD -----
B103 01	2/18/13	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002339000
	2/18/13	AP	T/S: 02/14/2013 09:07 AM DJOHNSON ----- PLEASE CALL ROBBIE POPE AT 919-868-2912 WHEN GOING TO JOBSITE. T/S: 02/15/2013 09:22 AM VBROWN ----- T/S: 02/18/2013 02:36 PM KSLATTUM -----
B105 01	2/21/13	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002341600
	2/21/13	AP	T/S: 02/20/2013 01:54 PM VBROWN ----- T/S: 02/20/2013 01:54 PM VBROWN ----- KEN CALL ROBBIE POPE BEFORE YOU GO OUT LATER IN THE AM 919 868 2912 T/S: February 21, 2013 02:22 PM BSUTTON -----
R425 01	4/18/13	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002368595
			T/S: 04/17/2013 11:57 AM VBROWN ----- T/S: 04/17/2013 11:58 AM VBROWN ----- CONTRACTOR WANTS YOU TO CALL HIM. ROBBY 919 868 2912.

4-18-13 CAJV

per Robby

COMMENTS AND NOTES

ADDRESS : 340 WILLOWCROFT CT SUBDIV: LEIGH LAUREL
 CONTRACTOR : POPE ROBERT PHONE : (919) 868-2912
 OWNER : WALKER BRIAN K & PHONE : (910) 514-2370
 PARCEL : 02-1518- - -0099- -07-
 APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/04/2013 02:22 PM JBROCK ----
 340 WILLOWCROFT
 LEIGH LAUREL S/D LOT 4 ON
 PREMISE # 26828234
 LAND NOTES : LXMN 6/18/04 LEIGH LAUREL LOT#4
 LXMN 6/21/04 SPLIT FROM THE 03 PARCEL

STRUCTURE: 000 000 98.9X62.3 3BDR CRAWL W/ GARAGE & DECK
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/31/13	BS	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002332898
	1/31/13	AP	T/S: January 31, 2013 01:03 PM BSUTTON -----
A814 01	2/15/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002339018
	2/19/13	AP	T/S: 02/14/2013 09:11 AM DJOHNSON ----- 340 WILLOWCROFT CT LOT 4 DUNN 28334----- T/S: 02/19/2013 01:10 PM TWARD -----
B103 01	2/18/13	KS	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002339000
	2/18/13	AP	T/S: 02/14/2013 09:07 AM DJOHNSON ----- PLEASE CALL ROBBIE POPE AT 919-868-2912 WHEN GOING TO JOBSITE. T/S: 02/15/2013 09:22 AM VBROWN ----- T/S: 02/18/2013 02:36 PM KSLATTUM -----
B105 01	2/21/13	BS	R*OPEN FLOOR TIME: 17:00 VRU #: 002341600
	2/21/13	AP	T/S: 02/20/2013 01:54 PM VBROWN ----- T/S: 02/20/2013 01:54 PM VBROWN ----- KEN CALL ROBBIE POPE BEFORE YOU GO OUT LATER IN THE AM 919 868 2912 T/S: February 21, 2013 02:22 PM BSUTTON -----
R425 01	4/18/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002368595
	4/18/13	CA	T/S: 04/17/2013 11:57 AM VBROWN ----- T/S: 04/17/2013 11:58 AM VBROWN ----- CONTRACTOR WANTS YOU TO CALL HIM. ROBBY 919 868 2912. PER ROBBY -----
R425 02	4/22/13	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002370310
	4/22/13	DA	call cell number when going to inspection 919-868-2912 T/S: 04/22/2013 01:08 PM DETAYLOR ----- 1. Missing joist hangers in dining room/by back porch door/and for triple joist. 2. Completely nail all hangers 3. Missing air barriers throughout house 4. Fire block around hood vent 5. Fire block chase to left of fireplace where line set passes 6. Need receptacle accessible from grade on rear of house 7. Fire caulk plumbing for upstairs bath 8. Fasten exhaust duct to fan in upstairs bath 9. Front door must be inspected after installation 10. Support (circled on plans)missing under wall at upstairs

ADDRESS . . : 340 WILLOWCROFT CT
CONTRACTOR : POPE ROBERT
OWNER . . . : WALKER BRIAN K &
PARCEL . . . : 02-1518- - -0099- -07-
APPL NUMBER: 13-50030361 CP NEW RESIDENTIAL (SFD)

SUBDIV: LEIGH LAUREL
PHONE : (919) 868-2912
PHONE : (910) 514-2370

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
I129 01	<u>4/26/13</u> 4-26	TI <i>AP</i>	porch R*INSULATION INSPECTION TIME: 17:00 VRU #: 002373462 T/S: 04/25/2013 01:15 PM VBROWN -----
R425 03	<u>4/26/13</u> 4-26	TI <i>AP</i>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002373488 T/S: 04/25/2013 01:15 PM VBROWN -----

----- COMMENTS AND NOTES -----