

County of Harnett
Building Inspections Department
Planning Services

Certificate of Compliance: _____ Occupancy: X

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Permit Numbers

Name: Weaver Development Inc

Building: 13-50030421

Electrical: 13-50030421

Address: 379 Juno Drive

Insulation: 13-50030421

Broadway NC 27505

Plumbing: 13-50030421

Mechanical: 13-50030421

MFG Home: NANANANANA

Date: 03-27-2013

Building Official: BSutton

ADDRESS : 379 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576-01- -0088- -51-
 APPL NUMBER: 13-50030421 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/15/2013 09:32 AM VBROWN ----
 379 JUNO DRIVE TINGEN POINTE #147. 27W
 GO PAST WHHS ABOUT 4MI, TINGEN POINTE
 ON THE LEFT, TAKE JUNO DRIVE AND DU HOC
 IS THE FIRST LEFT #147 ON THE LEFT.

STRUCTURE: 000 000 59X40 3BDR 2BATH SFD W GAR DECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/06/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002334738
	2/06/13	AP	T/S: 02/06/2013 01:15 PM MREARIC premise# 03469151
B103 01	2/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002337160
	2/11/13	AP	T/S: 02/11/2013 01:14 PM MREARIC
A814 01	2/11/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002337178
	2/19/13	AP	379 JUNO DR LOT-147 BROADWAY-27505 T/S: 02/19/2013 01:05 PM TWARD
B114 01	2/12/13	MR	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002337533
	2/12/13	AP	T/S: 02/11/2013 09:50 AM DJOHNSON T/S: 02/12/2013 12:51 PM MREARIC
P309 01	2/12/13	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002337541
	2/12/13	AP	T/S: 02/11/2013 09:50 AM DJOHNSON T/S: 02/12/2013 12:51 PM MREARIC
R425 01	2/25/13	MR	FOUR TRADE ROUGH IN VRU #: 002341816
	2/25/13	DA	T/S: 02/25/2013 12:43 PM MREARIC hinge wall, dryer vent length, air barrier holes, attic walkway, ok to side and ins.
I129 01	2/27/13	FS	R*INSULATION INSPECTION VRU #: 002343234
	2/27/13	AP	T/S: 02/27/2013 02:53 PM FSPIVEY
R425 02	2/27/13	FS	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002344364
	2/27/13	AP	T/S: 02/26/2013 03:38 PM DJOHNSON MAKE SURE ROUGH IN INSPECTION IS ALSO CALLED WITH INSULATION INSPECTION IF THE ROUGH IN FAILED. THE INSULATION INSPECTION CAN BE CANCELLED IF NOT. T/S: 02/27/2013 02:53 PM FSPIVEY
H824 01	3/07/13	OT	ENVR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002349694
	3/07/13	AP	T/S: 03/08/2013 11:09 AM SSTEWARD T/S: 03/08/2013 11:10 AM SSTEWARD
R429 01	3/26/13	BS	FOUR TRADE FINAL VRU #: 002356756
	3/26/13	CA	T/S: March 26, 2013 10:18 AM BSUTTON
R429 02	3/27/13	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002357465

COMMENTS AND NOTES

ADDRESS : 379 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576-01- -0088- -51-
 APPL NUMBER: 13-50030421 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/15/2013 09:32 AM VBROWN ----
 379 JUNO DRIVE TINGEN POINTE #147. 27W
 GO PAST WHHS ABOUT 4MI, TINGEN POINTE
 ON THE LEFT, TAKE JUNO DRIVE AND DU HOC
 IS THE FIRST LEFT #147 ON THE LEFT.

STRUCTURE: 000 000 59X40 3BDR 2BATH SFD W GAR DECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED	INSP	DESCRIPTION
	COMPLETED	RESULT	RESULTS/COMMENTS
B101 01	2/06/13	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002334738
	<i>2-6-13</i>	<i>AP-MR</i>	

----- COMMENTS AND NOTES -----

03469151

ADDRESS : 379 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576-01- -0088- -51-
 APPL NUMBER: 13-50030421 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 01/15/2013 09:32 AM VBROWN ----
 379 JUNO DRIVE TINGEN POINTE #147. 27W
 GO PAST WHHS ABOUT 4MI, TINGEN POINTE
 ON THE LEFT, TAKE JUNO DRIVE AND DU HOC
 IS THE FIRST LEFT #147 ON THE LEFT.

STRUCTURE: 000 000 59X40 3BDR 2BATH SFD W GAR DECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/06/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002334738
	2/06/13	AP	T/S: 02/06/2013 01:15 PM MREARIC ----- premise# 03469151
A814 01	2/11/13	TI	ADDRESS CONFIRMATION VRU #: 002337178
B103 01	2/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002337160
	2/11/13	AP	T/S: 02/11/2013 01:14 PM MREARIC -----
B114 01	2/12/13	TI	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002337533
	<u>2-12-13</u>	<u>AP-MR</u>	T/S: 02/11/2013 09:50 AM DJOHNSON -----
P309 01	2/12/13	TI	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002337541
	<u>2-11-13</u>	<u>AP-MR</u>	T/S: 02/11/2013 09:50 AM DJOHNSON -----

----- COMMENTS AND NOTES -----

ADDRESS : 379 JUNO DR SUBDIV: TINGEN POINTE PH 5 33LOTS
 CONTRACTOR : WEAVER DEVELOPMENT CO INC PHONE : (910) 433-0888
 OWNER : THE HARNETT LAND GROUP II LLC PHONE :
 PARCEL : 03-9576-01- -0088- -51-
 APPL NUMBER: 13-50030421 CP NEW RESIDENTIAL (SFD)

DIRECTIONS : T/S: 01/15/2013 09:32 AM VBROWN ----
 379 JUNO DRIVE TINGEN POINTE #147. 27W
 GO PAST WHHS ABOUT 4MI, TINGEN POINTE
 ON THE LEFT, TAKE JUNO DRIVE AND DU HOC
 IS THE FIRST LEFT #147 ON THE LEFT.

STRUCTURE: 000 000 59X40 3BDR 2BATH SFD W GAR DECK SLAB
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 3.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/06/13 2/06/13	MR AP	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002334738 T/S: 02/06/2013 01:15 PM MREARIC ----- premise# 03469151
B103 01	2/11/13 2/11/13	MR AP	R*BLDG FOUND & TEMP SVC POLE VRU #: 002337160 T/S: 02/11/2013 01:14 PM MREARIC -----
A814 01	2/11/13 2/19/13	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002337178 379 JUNO DR LOT 147 BROADWAY 27505 ----- T/S: 02/19/2013 01:05 PM TWARD -----
B114 01	2/12/13 2/12/13	MR AP	R*BLDG MONO SLAB/TEMP SVC POLE TIME: 17:00 VRU #: 002337533 T/S: 02/11/2013 09:50 AM DJOHNSON ----- T/S: 02/12/2013 12:51 PM MREARIC -----
P309 01	2/12/13 2/12/13	MR AP	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002337541 T/S: 02/11/2013 09:50 AM DJOHNSON ----- T/S: 02/12/2013 12:51 PM MREARIC -----
R425 01	2/25/13 2/25/13	MR DA	FOUR TRADE ROUGH IN VRU #: 002341816 T/S: 02/25/2013 12:43 PM MREARIC ----- hinge wall, dryer vent length, air barrier holes, attic walkway, ok to side and ins.
I129 01	2/27/13 <i>2-27-13</i>	TI <i>AP</i>	R*INSULATION INSPECTION VRU #: 002343234
R425 02	2/27/13 <i>2-27-13</i>	TI <i>AP</i>	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002344364 T/S: 02/26/2013 03:38 PM DJOHNSON ----- MAKE SURE ROUGH IN INSPECTION IS ALSO CALLED WITH INSULATION INSPECTION IF THE ROUGH IN FAILED. THE INSULATION INSPECTION CAN BE CANCELLED IF NOT.

COMMENTS AND NOTES