

**COUNTY OF HARNETT**  
**Building Inspections Department**  
**Planning Services**

**Certificate of Compliance:** \_\_\_\_\_ **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: SFD

Name: Bill Clark Homes LLC

Address: 61 Carolina Oaks Cir

\_\_\_\_\_

\_\_\_\_\_

Date: 8-26-13

Building Official: James T. Hall

**Permit Numbers**

Building: \_\_\_\_\_

Electrical: \_\_\_\_\_

Insulation: \_\_\_\_\_

Plumbing: \_\_\_\_\_

Mechanical: \_\_\_\_\_

MFG Home: \_\_\_\_\_

*13-5005-21*

ADDRESS : 61 CAROLINA OAKS CIR  
 CONTRACTOR : BILL CLARK HOMES LLC  
 OWNER : BILL CLARK HOMES LLC  
 PARCEL : 01-0544- - -0012- -43-  
 APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
 HWY 401 S TO ELLIOTT BRIDGE RD R ON  
 ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
 RD THEN R INTO CAROLINA OAKS ON  
 CAROLINA OAKS CIR LOT 43

SUBDIV: CAROLINA OAKS 64 LOTS  
 PHONE : (252) 355-5805  
 PHONE :

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00  
 SEPTIC - EXISTING? : NEW  
 PROPOSED USE : SFD  
 WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360
	2/26/13	CA	PER PAUL
B101 02	3/06/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002347507
	3/06/13	AP	T/S: 03/06/2013 10:56 AM DETAYLOR
A814 01	3/12/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002350551
	3/21/13	CA	T/S: 03/11/2013 01:06 PM VBROWN 681 CAROLINA OAKS CIR LOT 43 LINDEN 28356 T/S: 03/21/2013 04:34 PM TWARD T/S: 08/23/2013 09:08 AM TWARD
B103 01	3/12/13	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002350544
	3/12/13	CA	T/S: 03/11/2013 01:06 PM VBROWN PER PAUL
B103 02	3/13/13	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002351062
	3/13/13	AP	T/S: 03/13/2013 02:02 PM DETAYLOR
P309 01	3/21/13	JH	R*PLUMB UNDER SLAB VRU #: 002354561
	3/21/13	DA	not ready
P309 02	3/25/13	DT	R*PLUMB UNDER SLAB VRU #: 002355999
	3/25/13	AP	T/S: 03/25/2013 09:14 AM DETAYLOR
B111 01	3/26/13	DT	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002356532
	3/26/13	AP	T/S: 03/26/2013 12:32 PM DETAYLOR
R425 01	4/19/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369379
	4/19/13	CA	PER PAUL
R425 02	4/24/13	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002371524
	4/24/13	DA	T/S: 04/24/2013 09:03 AM DETAYLOR Seal air barriers throughout house C2G truss needs two hurricane straps on inside wall. Current strap is installed incorrectly Fire block top plate around master tub and shower Okay to side, do not insulate
R425 03	4/25/13	JH	FOUR TRADE ROUGH IN VRU #: 002372364
	4/25/13	AP	
I129 01	4/29/13	JH	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002374015
	4/29/13	AP	
H824 01	5/21/13	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002386779
	5/22/13	AP	T/S: 05/23/2013 11:17 AM SSTEWARD T/S: 05/23/2013 11:20 AM SSTEWARD

ADDRESS : 61 CAROLINA OAKS CIR  
CONTRACTOR : BILL CLARK HOMES LLC  
OWNER : BILL CLARK HOMES LLC  
PARCEL : 01-0544- - -0012- -43-  
APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)

SUBDIV: CAROLINA OAKS 64 LOTS  
PHONE : (252) 355-5805  
PHONE :

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
A814 02	8/23/13 8/23/13	TW AP	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002430536 61 CAROLINA OAKS CIR LINDEN 28356 T/S: 08/23/2013 09:09 AM TWARD
R429 01	8/23/13 8/23/13	JH DA	FOUR TRADE FINAL TIME: 17:00 VRU #: 002430114 T/S: 08/22/2013 01:09 PM DJOHNSON Missing support under all exterior door thresholds. Need a carbon monoxide detector outside of bed2 & 3. Wrong address on house correct address should be 61. Loose wire in pannel on #15 breaker.
R429 02	8/26/13 <i>8-26-13</i>	TI <i>AP JH</i>	FOUR TRADE FINAL TIME: 17:00 VRU #: 002430619 T/S: 08/23/2013 10:30 AM VBROWN

COMMENTS AND NOTES

-----  
ADDRESS . . : 681 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . . : BILL CLARK HOMES LLC PHONE :  
PARCEL . . . : 01-0544- - -0012- -43-  
APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
HWY 401 S TO ELLIOTT BRIDGE RD R ON  
ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
RD THEN R INTO CAROLINA OAKS ON  
CAROLINA OAKS CIR LOT 43  
-----

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE  
FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . . : 3000000.00 PROPOSED USE . . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW WATER SUPPLY . . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13 <i>CAJH</i>	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360 <i>per Paul</i>

-----  
COMMENTS AND NOTES  
-----

-----

ADDRESS . . : 681 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER . . . : BILL CLARK HOMES LLC PHONE :  
 PARCEL . . . : 01-0544- - -0012- -43-  
 APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
 HWY 401 S TO ELLIOTT BRIDGE RD R ON  
 ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
 RD THEN R INTO CAROLINA OAKS ON  
 CAROLINA OAKS CIR LOT 43

-----

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE  
 FLOOD ZONE . . . . : FLOOD ZONE X  
 # BEDROOMS . . . . : 3000000.00 PROPOSED USE . . . . : SFD  
 SEPTIC - EXISTING? . . . : NEW WATER SUPPLY . . . . : COUNTY

-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360
	2/26/13	CA	PER PAUL
B101 02	3/06/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002347507
	3/06/13	AP	T/S: 03/06/2013 10:56 AM DETAYLOR -----
A814 01	3/12/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002350551
			T/S: 03/11/2013 01:06 PM VBROWN -----
B103 01	3/12/13	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002350544
	<u>3-12-13</u>	<u>CA JH</u>	T/S: 03/11/2013 01:06 PM VBROWN -----

*Per Paul*  
 -----  
 COMMENTS AND NOTES

ADDRESS : 681 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER : BILL CLARK HOMES LLC PHONE :  
 PARCEL : 01-0544- - -0012- -43-  
 APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
 HWY 401 S TO ELLIOTT BRIDGE RD R ON  
 ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
 RD THEN R INTO CAROLINA OAKS ON  
 CAROLINA OAKS CIR LOT 43

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360
	2/26/13	CA	PER PAUL
B101 02	3/06/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002347507
	3/06/13	AP	T/S: 03/06/2013 10:56 AM DETAYLOR
A814 01	3/12/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002350551
			T/S: 03/11/2013 01:06 PM VBROWN
B103 01	3/12/13	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002350544
	3/12/13	CA	T/S: 03/11/2013 01:06 PM VBROWN
			PER PAUL
B103 02	3/13/13	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002351062
	3/13/13	AP	T/S: 03/13/2013 02:02 PM DETAYLOR
P309 01	3/21/13	TI	R*PLUMB UNDER SLAB VRU #: 002354561

*3-21-13 OATH*

*not Ready*

COMMENTS AND NOTES

-----  
ADDRESS : 681 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE :  
PARCEL : 01-0544- - -0012- -43-  
APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
HWY 401 S TO ELLIOTT BRIDGE RD R ON  
ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
RD THEN R INTO CAROLINA OAKS ON  
CAROLINA OAKS CIR LOT 43  
-----

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360
	2/26/13	CA	PER PAUL
B101 02	3/06/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002347507
	3/06/13	AP	T/S: 03/06/2013 10:56 AM DETAYLOR
A814 01	3/12/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002350551
	3/21/13	AP	T/S: 03/11/2013 01:06 PM VBROWN 681 CAROLINA OAKS CIR LOT 43 LINDEN 28356 T/S: 03/21/2013 04:34 PM TWARD
B103 01	3/12/13	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002350544
	3/12/13	CA	T/S: 03/11/2013 01:06 PM VBROWN PER PAUL
B103 02	3/13/13	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002351062
	3/13/13	AP	T/S: 03/13/2013 02:02 PM DETAYLOR
P309 01	3/21/13	JH	R*PLUMB UNDER SLAB VRU #: 002354561
	3/21/13	DA	not ready
P309 02	3/25/13	DT	R*PLUMB UNDER SLAB VRU #: 002355999
	3/25/13	AP	T/S: 03/25/2013 09:14 AM DETAYLOR
B111 01	3/26/13	DT	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002356532
	3/26/13	AP	T/S: 03/26/2013 12:32 PM DETAYLOR
R425 01	4/19/13	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369379

4-19-13 *CA JH*  
*per Paul*

-----  
COMMENTS AND NOTES  
-----

ADDRESS : 681 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER : BILL CLARK HOMES LLC PHONE :  
 PARCEL : 01-0544- - -0012- -43-  
 APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
 HWY 401 S TO ELLIOTT BRIDGE RD R ON  
 ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
 RD THEN R INTO CAROLINA OAKS ON  
 CAROLINA OAKS CIR LOT 43

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360
	2/26/13	CA	PER PAUL
B101 02	3/06/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002347507
	3/06/13	AP	T/S: 03/06/2013 10:56 AM DETAYLOR
A814 01	3/12/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002350551
	3/21/13	AP	T/S: 03/11/2013 01:06 PM VBROWN 681 CAROLINA OAKS CIR LOT 43 LINDEN 28356 T/S: 03/21/2013 04:34 PM TWARD
B103 01	3/12/13	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002350544
	3/12/13	CA	T/S: 03/11/2013 01:06 PM VBROWN PER PAUL
B103 02	3/13/13	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002351062
	3/13/13	AP	T/S: 03/13/2013 02:02 PM DETAYLOR
P309 01	3/21/13	JH	R*PLUMB UNDER SLAB VRU #: 002354561
	3/21/13	DA	not ready
P309 02	3/25/13	DT	R*PLUMB UNDER SLAB VRU #: 002355999
	3/25/13	AP	T/S: 03/25/2013 09:14 AM DETAYLOR
B111 01	3/26/13	DT	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002356532
	3/26/13	AP	T/S: 03/26/2013 12:32 PM DETAYLOR
R425 01	4/19/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369379
	4/19/13	CA	PER PAUL
R425 02	4/24/13	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002371524
	4/24/13	DA	T/S: 04/24/2013 09:03 AM DETAYLOR Seal air barriers throughout house C2G truss needs two hurricane straps on inside wall. Current strap is installed incorrectly Fire block top plate around master tub and shower Okay to side, do not insulate
R425 03	4/25/13	TJ	FOUR TRADE ROUGH IN VRU #: 002372364

4-25-13 *ACTH*

COMMENTS AND NOTES



ADDRESS : 681 CAROLINA OAKS CIR SUBDIV: CAROLINA OAKS 64 LOTS  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER : BILL CLARK HOMES LLC PHONE :  
 PARCEL : 01-0544- - -0012- -43-  
 APPL NUMBER: 13-50030522 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 01/30/2013 09:26 AM JBROCK ----  
 HWY 401 S TO ELLIOTT BRIDGE RD R ON  
 ELLIOTT BRIDGE TRU NR ONTO WILL LUCAS  
 RD THEN R INTO CAROLINA OAKS ON  
 CAROLINA OAKS CIR LOT 43

STRUCTURE: 000 000 54.6X57.6 3BDR SLAB W/ GARAGE  
 FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	JH	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343360
	2/26/13	CA	PER PAUL
B101 02	3/06/13	DT	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002347507
	3/06/13	AP	T/S: 03/06/2013 10:56 AM DETAYLOR
A814 01	3/12/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002350551
	3/21/13	AP	T/S: 03/11/2013 01:06 PM VBROWN 681 CAROLINA OAKS CIR LOT 43 LINDEN 28356 T/S: 03/21/2013 04:34 PM TWARD
B103 01	3/12/13	JH	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002350544
	3/12/13	CA	T/S: 03/11/2013 01:06 PM VBROWN PER PAUL
B103 02	3/13/13	DT	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002351062
	3/13/13	AP	T/S: 03/13/2013 02:02 PM DETAYLOR
P309 01	3/21/13	JH	R*PLUMB UNDER SLAB VRU #: 002354561
	3/21/13	DA	not ready
P309 02	3/25/13	DT	R*PLUMB UNDER SLAB VRU #: 002355999
	3/25/13	AP	T/S: 03/25/2013 09:14 AM DETAYLOR
B111 01	3/26/13	DT	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002356532
	3/26/13	AP	T/S: 03/26/2013 12:32 PM DETAYLOR
R425 01	4/19/13	JH	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369379
	4/19/13	CA	PER PAUL
R425 02	4/24/13	DT	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002371524
	4/24/13	DA	T/S: 04/24/2013 09:03 AM DETAYLOR Seal air barriers throughout house C2G truss needs two hurricane straps on inside wall. Current strap is installed incorrectly Fire block top plate around master tub and shower Okay to side, do not insulate
R425 03	4/25/13	JH	FOUR TRADE ROUGH IN VRU #: 002372364
	4/25/13	AP	
I129 01	4/29/13	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002374015

*4-29-13 [Signature]*

COMMENTS AND NOTES