

COUNTY OF HARNETT  
Building Inspections Department  
Planning Services

**Certificate of Compliance:**     X     **Occupancy:**     X    

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification:     RS    

Name:     Bill Clark Homes LLC    

Address:     485 Fifty Coliper    

**Permit Numbers**

Building:     13-50030556    

Electrical:                     "    

Insulation:                     "    

Plumbing:                     "    

Mechanical:                     "    

MFG Home:                     "    

    Date: 9-20-13    

    Building Official: T. Michael Reaie

ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
 CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
 OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
 PARCEL : 03-9597- - -0039- -21-  
 APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
 DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
 PATTONS POINT 485 FIFTY CALIBER DR LOT  
 24

STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X  
 # BEDROOMS : 3000000.00 PROPOSED USE : SFD  
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642
	3/20/13	AP	T/S: 03/20/2013 02:17 PM FSPIVEY -----
A814 01	4/16/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002366698
	4/25/13	AP	485 FIFTY CALIBER DR LOT 24 BROADWAY 27505--- T/S: 04/25/2013 03:49 PM TWARD -----
R425 01	4/16/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002366706
	4/16/13	DA	T/S: 04/16/2013 01:18 PM MREARIC ----- attic floor to shallow for R-38 insulation
R425 02	4/19/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369361
	4/19/13	AP	T/S: 04/19/2013 01:26 PM MREARIC -----
I129 01	4/23/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371128
	4/23/13	CA	pre paul
I129 02	4/24/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371508
	4/24/13	DA	T/S: 04/24/2013 12:07 PM MREARIC ----- 1. air barriers are needed at insulation in attic 2. no way to blow in insulation (no access) 3. insulation needed at 2nd fl. edges
I129 03	4/25/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002372647
	4/25/13	AP	AFTER LUNCH IF POSSIBLE T/S: 04/25/2013 01:53 PM MREARIC -----
H824 01	9/17/13	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002442218
	9/17/13	AP	
R429 01	9/20/13	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002442226

16 *AP-MR*

COMMENTS AND NOTES

PREPARED 2/25/13, 14:04:34  
Harnett County

INSPECTION TICKET  
INSPECTOR: IVR

PAGE 39  
DATE 2/26/13

-----  
ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

**STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351

           CA-MR

----- COMMENTS AND NOTES -----

-----  
ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	TI	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	<u>3-1-13</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----  
-----

-----  
ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE  
FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	TI	R*PLUMB UNDER SLAB VRU #: 002352750
	<u>3-18-13</u>	<u>AP-MR</u>	

----- COMMENTS AND NOTES -----

~~Slab ins~~  
Found. insulated

-----  
ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

**STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE**

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	TI	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642

*3-20-13* *AYO*

-----  
COMMENTS AND NOTES  
-----

*FS*

-----  
ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

**STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3000000.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642
	3/20/13	AP	T/S: 03/20/2013 02:17 PM FSPIVEY -----
A814 01	4/16/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002366698
R425 01	4/16/13	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002366706
	<u>4-16-13</u>	<u>DA-MR</u>	

----- COMMENTS AND NOTES -----

# VIOLATION NOTICE

## DO NOT REMOVE!

Harnett County Inspection Department

108 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7525 Ext. 1 • Fax: (910) 893-2793

Job Name: B. H. Clark Date: 4-16-13

Address: 485 Fifty Caliper

Lot No.: \_\_\_\_\_ Permit No.: \_\_\_\_\_

( Check Box for Violation )

- |                                     |                                     |                                  |  |                                     |                                       |                                 |                                      |
|-------------------------------------|-------------------------------------|----------------------------------|--|-------------------------------------|---------------------------------------|---------------------------------|--------------------------------------|
| <input type="checkbox"/> Footing    | <input type="checkbox"/> Foundation | <input type="checkbox"/> Bldg.   | <input type="checkbox"/> Elec.             | <input type="checkbox"/> Plumb.     | <input type="checkbox"/> Mech.        | <input type="checkbox"/> Insul. | <input type="checkbox"/> Floor Fram. |
| <input type="checkbox"/> Floor Slab | <input type="checkbox"/> MFG. Home  | <input type="checkbox"/> Modular | <input type="checkbox"/> Damp/Water Proof. | <input type="checkbox"/> Structural | <input type="checkbox"/> Wall Sheath. | <input type="checkbox"/> Other  |                                      |

Violations Found: \_\_\_\_\_

The Attic Floor does not  
Permit R-38. its only 2x8

Code Enforcement Official

Signature: MR Date: \_\_\_\_\_

It is unlawful for any subcontractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation



-----  
ADDRESS . . : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . . : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL . . . : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

**STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3000000.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . : NEW TANK WATER SUPPLY . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642
	3/20/13	AP	T/S: 03/20/2013 02:17 PM FSPIVEY -----
A814 01	4/16/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002366698
R425 01	4/16/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002366706
	4/16/13	DA	T/S: 04/16/2013 01:18 PM MREARIC ----- attic floor to shallow for R-38 insulation
R425 02	4/19/13	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369361

4-19-13 **AP-MR**

----- COMMENTS AND NOTES -----

-----  
ADDRESS . . : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . . : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL . . . : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

**STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE**

FLOOD ZONE . . . . : FLOOD ZONE X  
# BEDROOMS . . . . : 3000000.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . : NEW TANK WATER SUPPLY . . . . : COUNTY  
-----

**PERMIT: CPSF 00 CP \* SFD**

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642
	3/20/13	AP	T/S: 03/20/2013 02:17 PM FSPIVEY -----
A814 01	4/16/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002366698
R425 01	4/16/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002366706
	4/16/13	DA	T/S: 04/16/2013 01:18 PM MREARIC ----- attic floor to shallow for R-38 insulation
R425 02	4/19/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369361
	4/19/13	AP	T/S: 04/19/2013 01:26 PM MREARIC -----
I129 01	4/23/13	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371128
	<u>4-23-13</u>	<u>CA MR</u>	T/S: 04/22/2013 01:50 PM VBROWN -----

-----  
COMMENTS AND NOTES  
-----

ADDRESS : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24

STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE

FLOOD ZONE : FLOOD ZONE X  
# BEDROOMS : 3000000.00 PROPOSED USE : SFD  
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642
	3/20/13	AP	T/S: 03/20/2013 02:17 PM FSPIVEY -----
A814 01	4/16/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002366698
R425 01	4/16/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002366706
	4/16/13	DA	T/S: 04/16/2013 01:18 PM MREARIC ----- attic floor to shallow for R-38 insulation
R425 02	4/19/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369361
	4/19/13	AP	T/S: 04/19/2013 01:26 PM MREARIC -----
I129 01	4/23/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371128
	4/23/13	CA	pre paul
I129 02	4/24/13	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371508

9-24-B DA-MR

COMMENTS AND NOTES

# VIOLATION NOTICE

## DO NOT REMOVE!

Harnett County Inspection Department

108 East Front Street • P.O. Box 65

Lillington, NC 27546

Phone: (910) 893-7525 Ext. 1 • Fax: (910) 893-2793

Job Name: \_\_\_\_\_ Date: 4-24-13

Address: 485 Fifty Caliper

Lot No.: \_\_\_\_\_ Permit No.: \_\_\_\_\_

( Check Box for Violation )

- |                          |                          |                          |                          |                          |                          |                          |                          |
|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|--------------------------|
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |
| Footing                  | Foundation               | Bldg.                    | Elec.                    | Plumb.                   | Mech.                    | Insul.                   | Floor Fram.              |
| <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> | <input type="checkbox"/> |                          |
| Floor Slab               | MFG. Home                | Modular                  | Damp/Water Proof.        | Structural               | Wall Sheath.             | Other                    |                          |

Violations Found: \_\_\_\_\_

1) No Air Barriers in Attic in Spots

2) No way to properly blow in insulation in other spots

3) Insul. needed in 2nd fl at edges

Code Enforcement Official

Signature: \_\_\_\_\_ Date: \_\_\_\_\_

It is unlawful for any subcontractor, general contractor, or owner to cover or cause to be covered any part of the work with flooring, sheetrock, earth or other material until the proper inspector had ample time to approve the installation

-----  
ADDRESS . . : 485 FIFTY CALIBER DR SUBDIV: PATTONS POINT  
CONTRACTOR : BILL CLARK HOMES LLC PHONE : (252) 355-5805  
OWNER . . . : BILL CLARK HOMES LLC PHONE : (910) 426-2898  
PARCEL . . . : 03-9597- - -0039- -21-  
APPL NUMBER: 13-50030556 CP NEW RESIDENTIAL (SFD)  
DIRECTIONS : T/S: 02/04/2013 10:59 AM JBROCK ----  
PATTONS POINT 485 FIFTY CALIBER DR LOT  
24  
-----

STRUCTURE: 000 000 39X34 3BDR SLAB W/ GARAGE

FLOOD ZONE . . . . : FLOOD'ZONE X  
# BEDROOMS . . . . : 3000000.00 PROPOSED USE . . . . : SFD  
SEPTIC - EXISTING? . . . . : NEW TANK WATER SUPPLY . . . . : COUNTY  
-----

PERMIT: CPSF 00 CP \* SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	2/26/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002343351
	2/26/13	CA	T/S: 02/26/2013 11:55 AM MREARIC -----
B101 02	3/01/13	MR	R*BLDG FOOTING / TEMP SVC POLE VRU #: 002345108
	3/01/13	AP	T/S: 03/01/2013 01:56 PM MREARIC -----
B103 01	3/11/13	MR	R*BLDG FOUND & TEMP SVC POLE VRU #: 002349587
	3/11/13	AP	
P309 01	3/18/13	MR	R*PLUMB UNDER SLAB VRU #: 002352750
	3/18/13	AP	T/S: 03/18/2013 01:58 PM MREARIC -----
B111 01	3/20/13	FS	R*BLDG SLAB INSP/TEMP SVC POLE VRU #: 002353642
	3/20/13	AP	T/S: 03/20/2013 02:17 PM FSPIVEY -----
A814 01	4/16/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002366698
R425 01	4/16/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002366706
	4/16/13	DA	T/S: 04/16/2013 01:18 PM MREARIC ----- attic floor to shallow for R-38 insulation
R425 02	4/19/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002369361
	4/19/13	AP	T/S: 04/19/2013 01:26 PM MREARIC -----
I129 01	4/23/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371128
	4/23/13	CA	pre paul
I129 02	4/24/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002371508
	4/24/13	DA	T/S: 04/24/2013 12:07 PM MREARIC ----- 1. air barriers are needed at insulation in attic 2. no way to blow in insulation (no access) 3. insulation needed at 2nd fl. edges
I129 03	4/25/13	TI	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002372647
	<u>4-25-13</u>	<u>AP-MR</u>	AFTER LUNCH IF POSSIBLE

-----  
COMMENTS AND NOTES  
-----