HTE#13-5-30596 Harnett County Department of Pub Health

Improvement Permit

27271

A building permit cannot be issued with only an Improvement Permit PROPERTY LOCATION: Docs Co McKEE HOMES ISSUED TO: SUBDIVISION OAKMOT NEW X EXPANSION Site Improvements required prior to Construction Authorization Issuance: SED Type of Structure: 25% REDUCTION Proposed Wastewater System Type: Projected Daily Flow: 480 Number of Occupants: Number of bedrooms: Basement Yes No. ☐ May be required based on final location and elevations of facilities Pump Required: ☐Yes Type of Water Supply:

Community Public

Well Distance from well LOO feet Permit valid for: ■ No expiration SEE ATTACHED SITE SKETCH Authorized State Agent:: The issuance of this permit by the Health Department in no way guarantees the issuance at other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.. Construction Authorization (Required for Building Permit) The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout. ISSUED TO: McKEE Homes PROPERTY LOCATION: Does Ro SUBDIVISION DEXMONT Facility Type: 550 (36×57) New Expansion Basement Fixtures? Tes No No System (Initial) Wastewater Flow: 480 Basement? Yes No Basement Fixtures? Yes Type of Wastewater System** GPD (See note below, if applicable

) 25% REDUCTION Installation Requirements/Conditions Number of trenches Exact length of each trench 75 feet Trench Spacing: 7 Feet on Center Septic Tank Size 1000 gallons Soil Cover: 6-24 Pump Tank Size gallons Trenches shall be installed on contour at a Maximum Trench Depth of: 36-39 inches (Maximum soil cover shall not exceed (Trench bottoms shall be level to +/-1/4" 36" above the trench bottom) in all directions) Pump Requirements: ft. TDH vs. GPM _ inches below pipe inches above pipe Conditions: inches total WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA. **If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit. Owner/Legal Representative Signature: This Construction Authorization is subject to revocation if the site plan plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject aws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH Authorized State Agent: Construction Authorization Expiration Date:

Harnett County Department of Public Health Site Sketch

Authorized State Agent:

PROPERTY LOCATON: Docs Ro

SUBDIVISION DAKMONT

LOT # 14)

Date: 2/19/13

