

COUNTY OF HARNETT
Building Inspections Department
Planning Services

Certificate of Compliance: X **Occupancy:** ✓

Certificate issued pursuant to the requirements of North Carolina General Statute 153A-363 and Harnett County Zoning Ordinances. This certifies at the time of issuance, this structure was in compliance with the various ordinances of the County of Harnett and the North Carolina State Building Codes. For the following:

Use Classification: R-3

Name: H + H Constructors Inc.

Address: 41 Blue Jay Ct

Date: 6-27-13

Building Official: T. Michael Pearson

Permit Numbers

Building: 1350030612

Electrical: 11

Insulation: 11

Plumbing: 11

Mechanical: 1

MFG Home:

ADDRESS : 41 BLUE JAY CT SUBDIV: OAKMONT PH1 SECT2 25LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : OAKMONT DEV PTNRS LLC PHONE :
 PARCEL : 03-0507- - -0046- -46-
 APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
 TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
 MILES TURN L INTO S/D LOT 41

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE
 FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/20/13	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002354009
	3/20/13	AP	T/S: 03/20/2013 01:30 PM MREARIC -----
A814 01	4/01/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002358869
	4/04/13	AP	41 BLUE JAY CT LOT 41 LILLINGTON 27546
			T/S: 04/04/2013 04:35 PM TWARD -----
B103 01	4/01/13	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002358851
	4/01/13	DA	T/S: 04/01/2013 01:22 PM MREARIC ----- foundation must be damp-proofed to grade
B103 02	4/05/13	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002361954
	4/05/13	AP	T/S: 04/05/2013 01:45 PM MREARIC -----
B105 01	4/05/13	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 002361962
	4/05/13	AP	per mike - matt could go ahead and do the open floor
			T/S: 04/05/2013 01:45 PM MREARIC -----
B104 01	5/07/13	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002378644
	5/07/13	AP	T/S: 05/07/2013 01:00 PM JBROCK -----
R425 01	5/08/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002378651
	5/08/13	DA	T/S: 05/08/2013 01:17 PM MREARIC ----- install windows crawlspc access is blocked by plumber and ac pipe in the future,,,, no drywall until rough has passed
R425 02	5/13/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002381077
	5/13/13	AE	T/S: 05/13/2013 01:39 PM MREARIC ----- check riser again, plumber changed tub...ok to ins.
I129 01	5/16/13	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002383362
	5/16/13	AP	T/S: 05/16/2013 02:26 PM MREARIC -----
R425 03	5/16/13	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002383388
	5/16/13	AP	T/S: 05/16/2013 02:26 PM MREARIC -----
H824 01	5/28/13	OT	✓ ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002388833
	5/28/13	AP	T/S: 05/29/2013 10:47 AM SSTEWARD ----- T/S: 05/29/2013 10:48 AM SSTEWARD ----- T/S: 05/29/2013 10:49 AM SSTEWARD -----
E209 01	6/17/13	DT	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002397297
	6/17/13	CA	T/S: 06/17/2013 12:42 PM DETAYLOR -----
E209 02	6/21/13	JH	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002400372
	6/21/13	AP	-----
R429 01	6/27/13	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002403350

11 ~~DAAR~~

COMMENTS AND NOTES

AP-MR

PREPARED 3/19/13, 13:56:00
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 27
DATE 3/20/13

ADDRESS : 41 BLUE JAY CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : OAKMONT DEV PTNRS LLC
PARCEL : 03-0507- - -0046- -46-
APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
MILES TURN L INTO S/D LOT 41

SUBDIV: OAKMONT PH1 SECT2 25LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 5000000.00
SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD
WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS		
B101 01	3/20/13	TI	R*BLDG FOOTING / TEMP SVC POLE	TIME: 17:00	VRU #: 002354009
	<u>3-20-13 AP-MR</u>				

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 04/01/2013

PERMIT # 13-50030612

ADDRESS: 41 blue Jay

1. Foundation must be damp-proofed from footer to grade
2. Ok to continue with open floor ,but after damp-proofing call in for another foundation inspection (before open floor)

Mike Rearic cell# (910) 984- 4772

ADDRESS : 41 BLUE JAY CT SUBDIV: OAKMONT PH1 SECT2 25LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : OAKMONT DEV PTNRS LLC PHONE :
 PARCEL : 03-0507- - -0046- -46-
 APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
 TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
 MILES TURN L INTO S/D LOT 41

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/20/13	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002354009
	3/20/13	AP	T/S: 03/20/2013 01:30 PM MREARIC -----
A814 01	4/01/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002358869
	4/04/13	AP	41 BLUE JAY CT LOT 41 LILLINGTON 27546
			T/S: 04/04/2013 04:35 PM TWARD -----
B103 01	4/01/13	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002358851
	4/01/13	DA	T/S: 04/01/2013 01:22 PM MREARIC ----- foundation must be damp-proofed to grade
B103 02	4/05/13	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002361954
	4/05/13	AP	T/S: 04/05/2013 01:45 PM MREARIC -----
B105 01	4/05/13	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 002361962
	4/05/13	AP	per mike - matt could go ahead and do the open floor
			T/S: 04/05/2013 01:45 PM MREARIC -----
B104 01	5/07/13	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002378644
	5/07/13	AP	T/S: 05/07/2013 01:00 PM JBROCK -----
R425 01	5/08/13	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002378651

5-8-13 DA:MP

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 05/08/2013

PERMIT # 13-50030612

ADDRESS: 41 blue jay

1. Install all the windows and tape tyvek to windows
2. Crawlspace access should be 22x30 but ac man and plumber have gotten in the way
3. In the future NO DRYWALL in house until rough inspection is complete

Mike Rearic cell# (910) 984- 4772

PREPARED 3/19/13, 13:56:00
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 27
DATE 3/20/13

ADDRESS : 41 BLUE JAY CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : OAKMONT DEV PTNRS LLC
PARCEL : 03-0507- - -0046- -46-
APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
MILES TURN L INTO S/D LOT 41

SUBDIV: OAKMONT PH1 SECT2 25LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 5000000.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

	REQUESTED	INSP	DESCRIPTION	
TYP/SQ	COMPLETED	RESULT	RESULTS/COMMENTS	
B101 01	3/20/13	TI	R*BLDG FOOTING / TEMP SVC POLE	TIME: 17:00 VRU #: 002354009
	<u>3.20.13</u>	<u>AP-MR</u>		

----- COMMENTS AND NOTES -----

PREPARED 3/19/13, 13:56:00
Harnett County

INSPECTION TICKET
INSPECTOR: IVR

PAGE 27
DATE 3/20/13

ADDRESS : 41 BLUE JAY CT
CONTRACTOR : H & H CONSTRUCTORS INC
OWNER : OAKMONT DEV PTNRS LLC
PARCEL : 03-0507- - -0046- -46-
APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
MILES TURN L INTO S/D LOT 41

SUBDIV: OAKMONT PH1 SECT2 25LOTS
PHONE : (910) 486-4864
PHONE :

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X

BEDROOMS : 5000000.00

SEPTIC - EXISTING? : NEW TANK

PROPOSED USE : SFD

WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS		
B101 01	3/20/13	TI	R*BLDG FOOTING / TEMP SVC POLE	TIME: 17:00	VRU #: 002354009

3-20-13 AP-MR

----- COMMENTS AND NOTES -----

ADDRESS : 41 BLUE JAY CT SUBDIV: OAKMONT PH1 SECT2 25LOTS
CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
OWNER : OAKMONT DEV PTNRS LLC PHONE :
PARCEL : 03-0507- - -0046- -46-
APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
MILES TURN L INTO S/D LOT 41

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE
FLOOD ZONE : FLOOD ZONE X
BEDROOMS : 5000000.00 PROPOSED USE : SFD
SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/20/13	MR	R*BLDG FOOTING / TEMP SVC POLE .TIME: 17:00 VRU #: 002354009
	3/20/13	AP	T/S: 03/20/2013 01:30 PM MREARIC -----
A814 01	4/01/13	TI	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002358869
B103 01	4/01/13	TI	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002358851
	<u>4-1-13</u>	<u>DA-MR</u>	

----- COMMENTS AND NOTES -----

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 04/01/2013

PERMIT # 13-50030612

ADDRESS: 41 blue Jay

1. Foundation must be damp-proofed from footer to grade
2. Ok to continue with open floor ,but after damp-proofing call in for another foundation inspection (before open floor)

Mike Rearic cell# (910) 984- 4772

ADDRESS : 41 BLUE JAY CT SUBDIV: OAKMONT PH1 SECT2 25LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : OAKMONT DEV PTNRS LLC PHONE :
 PARCEL : 03-0507- - -0046- -46-
 APPL NUMBER: 13-50030612 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
 TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
 MILES TURN L INTO S/D LOT 41

STRUCTURE: 000 000 65X65 5BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	3/20/13	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002354009
	3/20/13	AP	T/S: 03/20/2013 01:30 PM MREARIC -----
A814 01	4/01/13	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002358869
	4/04/13	AP	41 BLUE JAY CT LOT 41 LILLINGTON 27546
			T/S: 04/04/2013 04:35 PM TWARD -----
B103 01	4/01/13	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002358851
	4/01/13	DA	T/S: 04/01/2013 01:22 PM MREARIC ----- foundation must be damp-proofed to grade
B103 02	4/05/13	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002361954
	4/05/13	AP	T/S: 04/05/2013 01:45 PM MREARIC -----
B105 01	4/05/13	MR	R*OPEN FLOOR TIME: 17:00 VRU #: 002361962
	4/05/13	AP	per mike - matt could go ahead and do the open floor
			T/S: 04/05/2013 01:45 PM MREARIC -----
B104 01	5/07/13	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002378644
	5/07/13	AP	T/S: 05/07/2013 01:00 PM JBROCK -----
R425 01	5/08/13	TI	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002378651

5-8-13 DA IMP

COMMENTS AND NOTES

HARNETT COUNTY

Building Inspections Dept.

108 E. Front St.

Lillington, NC 27546

910-893-7525

DATE: 05/08/2013

PERMIT # 13-50030612

ADDRESS: 41 blue jay

1. Install all the windows and tape tyvek to windows
2. Crawlspace access should be 22x30 but ac man and plumber have gotten in the way
3. In the future NO DRYWALL in house until rough inspection is complete

Mike Rearic cell# (910) 984- 4772