

ADDRESS : 163 BISON LN SUBDIV: OAKMONT PH1 SECT2 25LOTS
 CONTRACTOR : H & H CONSTRUCTORS INC PHONE : (910) 486-4864
 OWNER : OAKMONT DEV PTNRS LLC PHONE :
 PARCEL : 03-0507- - -0046- -53-
 APPL NUMBER: 13-50030613 CP NEW RESIDENTIAL (SFD)
 DIRECTIONS : T/S: 02/11/2013 01:41 PM JBROCK ----
 TAKE 27 TO DOCS RD TURN L GO ABOUT 1.5
 MILES TURN L INTO S/D LOT 137

STRUCTURE: 000 000 54X61 5BDR CRAWL W/ GARAGE

FLOOD ZONE : FLOOD ZONE X
 # BEDROOMS : 5000000.00 PROPOSED USE : SFD
 SEPTIC - EXISTING? : NEW TANK WATER SUPPLY : COUNTY

PERMIT: CPSF 00 CP * SFD

TYP/SQ	REQUESTED COMPLETED	INSP RESULT	DESCRIPTION RESULTS/COMMENTS
B101 01	1/10/14	MR	R*BLDG FOOTING / TEMP SVC POLE TIME: 17:00 VRU #: 002483204
	1/10/14	AP	T/S: 01/10/2014 12:47 PM MREARIC
A814 01	1/15/14	TW	ADDRESS CONFIRMATION TIME: 17:00 VRU #: 002484582
	1/28/14	AP	163 bison ln lillington 27546
			T/S: 01/28/2014 08:49 AM TWARD
B103 01	1/15/14	MR	R*BLDG FOUND & TEMP SVC POLE TIME: 17:00 VRU #: 002484574
	1/15/14	AP	T/S: 01/15/2014 01:25 PM MREARIC
E207 01	1/23/14	MR	R*ELEC TEMP SERVICE POLE TIME: 17:00 VRU #: 002486991
	1/23/14	AP	pole is at the back right corner
			T/S: 01/23/2014 02:05 PM MREARIC
P309 01	1/23/14	MR	R*PLUMB UNDER SLAB TIME: 17:00 VRU #: 002486983
	1/23/14	AP	T/S: 01/23/2014 02:05 PM MREARIC
B111 01	2/03/14	MR	R*BLDG SLAB INSP/TEMP SVC POLE TIME: 17:00 VRU #: 002489938
	2/03/14	AP	T/S: 02/03/2014 01:21 PM MREARIC
B104 01	2/21/14	JB	R*FOUND & SETBACK VERIF SURVEY TIME: 17:00 VRU #: 002495471
	2/21/14	AP	T/S: 02/21/2014 10:35 AM JBROCK
R425 01	2/24/14	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002495489
	2/24/14	DA	T/S: 02/24/2014 01:51 PM MREARIC
			no water in riser / possible leak in pipe by washer cold water
I129 01	2/26/14	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002496933
	2/26/14	DA	T/S: 02/26/2014 03:03 PM MREARIC
			leak at washer box
R425 02	2/26/14	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002496941
	2/26/14	DA	T/S: 02/26/2014 03:04 PM MREARIC
			leak at washer box
I129 02	2/27/14	MR	R*INSULATION INSPECTION TIME: 17:00 VRU #: 002497535
	2/27/14	AP	T/S: 02/27/2014 01:08 PM MREARIC
H824 01	3/11/14	OT	ENVIR. OPERATIONS PERMIT TIME: 17:00 VRU #: 002502540
	3/11/14	AP	T/S: 03/12/2014 02:20 PM SSTEWARD
			T/S: 03/12/2014 02:27 PM SSTEWARD
E209 01	4/01/14	MR	R*ELEC TEMP POWER CERT TIME: 17:00 VRU #: 002509685
	4/01/14	AP	T/S: 04/01/2014 01:33 PM MREARIC
R425 03	4/01/14	MR	FOUR TRADE ROUGH IN TIME: 17:00 VRU #: 002509677
	4/01/14	AP	insu ap'ed but not the rough-in - someone needs to fix
			T/S: 04/01/2014 01:33 PM MREARIC
R429 01	5/29/14	TI	FOUR TRADE FINAL TIME: 17:00 VRU #: 002533743