

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated: 3/1/13
 Proposed Facility: 4 BODM Design Flow (.1949): 480 gpd
 Location of Site: Property Recorded: Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Witness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2.5	0.6	G SL	VFN NS/MP					
		6.4A	SBX SCL*	FL SS/MP					PS .4
		4.4"	SM						
2		0.8	G S	VFN NS/MP					
		8.4R	SBX CL	FL SS/SR					PS .35

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	PUMP	25%	
Site LTAR	.35	.35	

3 x 115 @ 18.24'

