

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: Applicant: Date Evaluated: 2/27/2013
 Address: Design Flow (.1949): Property Size:
 Proposed Facility: Property Recorded:
 Location of Site: Public Individual Well Spring Other
 Water Supply: Auger Boring Pit Cut
 Evaluation Method: Sewage Industrial Process Mixed
 Type of Wastewater:

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
	LS 46	0-20	G/L5	VFNJNY					
		20-36	SBK/SC1	F-SSSP	10427/1 Q36				PS.5
		0-24	G/L5	VFNNSNP					
		24-36	SBK/SC1	F-SSSP					PS.5
		0-30	G/L5	VFNNSNP					
		36-42	SBK/SC1	F-SSSP					PS.6
		0-28	G/L5	VFNNSNP					
		28-34	SBK/SC1	F-SSSP					PS.5

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): PS Evaluated By: BA Others Present:
Available Space (.1945)	/	/	
System Type(s)	257c	257c	
Site LTAR	.5	.5	